

Chain of Custody Sheet	Monroe #1 BOCES Water Testing					Paradigm Environmental Services		EPA Action Level = 1,300 ug/L<	EPA Action Level = 15 ug/L<	Paradigm Report Page #
	Sample ID	Building	Room	Fixture	Address	Count	Result Cooper ug/L	Result Lead ug/L		
16	141	Bldg 1,2,3	A-3	Utility Sink	41 O'Connor Rd, Fairport 14450	143	120	1.2	150	
1	1	Bldg 1,2,3	A-Hall outside of A-5	Drinking Fountain	41 O'Connor Rd, Fairport 14450	1	260	1	8	
1	2B	Bldg 1,2,3	D-2	3 Bay Sink, Faucet Left	41 O'Connor Rd, Fairport 14450	3	350	1.8	10	
1	2A	Bldg 1,2,3	D-2	3 Bay Sink, Faucet Right	41 O'Connor Rd, Fairport 14450	2	410	1.3	9	
1	3	Bldg 1,2,3	D-2	Ice Machine	41 O'Connor Rd, Fairport 14450	4	10	1	11	
1	4B	Bldg 1,2,3	D-8	3 Bay Sink, Faucet Left	41 O'Connor Rd, Fairport 14450	6	460	2.2	13	
1	4A	Bldg 1,2,3	D-8	3 Bay Sink, Faucet Right	41 O'Connor Rd, Fairport 14450	5	420	2.7	12	
1	5	Bldg 1,2,3	D-8	Ice Machine	41 O'Connor Rd, Fairport 14450	7	400	4.2	14	
1	6	Bldg 1,2,3	E-5	Single Kitchen Sink, 1 faucet	41 O'Connor Rd, Fairport 14450	8	56	1.4	15	
1	7	Bldg 1,2,3	E-6a	Single Kitchen Sink, 1 faucet	41 O'Connor Rd, Fairport 14450	9	230	4.5	16	
1	8	Bldg 1,2,3	F-3, toward H-6C	Laundry sink	41 O'Connor Rd, Fairport 14450	10	390	4.5	17	
2	12B	Bldg 1,2,3	G-1	3 Bay Sink, Faucet Left	41 O'Connor Rd, Fairport 14450	15	550	3.6	22	
2	12A	Bldg 1,2,3	G-1	3 Bay Sink, Faucet Right	41 O'Connor Rd, Fairport 14450	14	470	1.1	21	
2	11	Bldg 1,2,3	G-1	Ice machine	41 O'Connor Rd, Fairport 14450	13	10	5.7	20	
2	10	Bldg 1,2,3	G-1	Single Kitchen Sink, 1 faucet	41 O'Connor Rd, Fairport 14450	12	440	1.0	19	
2	13B	Bldg 1,2,3	G-17	Single Kitchen sink drinking fountain	41 O'Connor Rd, Fairport 14450	17	400	1.0	24	
2	13A	Bldg 1,2,3	G-17	Single Kitchen Sink faucet	41 O'Connor Rd, Fairport 14450	16	360	1.0	23	
2	14B	Bldg 1,2,3	G-18	Single Kitchen sink drinking fountain	41 O'Connor Rd, Fairport 14450	19	140	1.0	26	
2	14A	Bldg 1,2,3	G-18	Single Kitchen Sink faucet	41 O'Connor Rd, Fairport 14450	18	290	1.0	25	
3	15B	Bldg 1,2,3	G-19	Single Kitchen sink drinking fountain	41 O'Connor Rd, Fairport 14450	21	160	1.0	28	
2	15A	Bldg 1,2,3	G-19	Single Kitchen Sink faucet	41 O'Connor Rd, Fairport 14450	20	250	1.0	27	
10	81	Bldg 1,2,3	G-20	Kitchen Sink	41 O'Connor Rd, Fairport 14450	85	280	1.0	92	
3	16B	Bldg 1,2,3	G-22	Single Kitchen sink drinking fountain	41 O'Connor Rd, Fairport 14450	23	290	1.1	30	
3	16A	Bldg 1,2,3	G-22	Single Kitchen Sink faucet	41 O'Connor Rd, Fairport 14450	22	250	1.5	29	
10	82	Bldg 1,2,3	G-Hall outside G-22	Drinking Fountain	41 O'Connor Rd, Fairport 14450	86	190	1.8	93	
2	9	Bldg 1,2,3	G-Hall outside H-2	Drinking fountain	41 O'Connor Rd, Fairport 14450	11	110	1.0	18	
3	17	Bldg 1,2,3	H-2	Single Kitchen Sink, 1 faucet	41 O'Connor Rd, Fairport 14450	24	67	2.4	31	
3	18	Bldg 1,2,3	H-9	Drinking Fountain	41 O'Connor Rd, Fairport 14450	25	190	1.0	32	
3	19	Bldg 1,2,3	H-9	Hot Beverage Vending Machine	41 O'Connor Rd, Fairport 14450	26	16	3.4	33	
11	99	Bldg 1,2,3	J-10	Kitchen Sink, Left	41 O'Connor Rd, Fairport 14450	103	280	5.7	110	
11	100	Bldg 1,2,3	J-10	Kitchen Sink, Right	41 O'Connor Rd, Fairport 14450	104	230	4.3	111	
11	98	Bldg 1,2,3	J-14	Drinking Fountain at Sink	41 O'Connor Rd, Fairport 14450	102	170	1.8	109	
11	97	Bldg 1,2,3	J-14	Sink Faucet	41 O'Connor Rd, Fairport 14450	101	190	1.6	108	
11	96	Bldg 1,2,3	J-15	Drinking Fountain at Sink	41 O'Connor Rd, Fairport 14450	100	130	2.3	107	
11	95	Bldg 1,2,3	J-15	Sink Faucet	41 O'Connor Rd, Fairport 14450	99	160	1.3	106	
11	92	Bldg 1,2,3	J-16	Drinking Fountain at Sink	41 O'Connor Rd, Fairport 14450	96	110	2.4	103	
11	91	Bldg 1,2,3	J-16	Kitchen Sink	41 O'Connor Rd, Fairport 14450	95	170	1.2	102	
11	93	Bldg 1,2,3	J-17	Kitchen Sink, Left	41 O'Connor Rd, Fairport 14450	97	1100	1.0	104	
11	94	Bldg 1,2,3	J-17	Kitchen Sink, Right	41 O'Connor Rd, Fairport 14450	98	460	1.0	105	
3	22B	Bldg 1,2,3	J-8	3 Bay Sink, Faucet Left	41 O'Connor Rd, Fairport 14450	29	350	1.7	36	
3	22A	Bldg 1,2,3	J-8	3 Bay Sink, Faucet Right	41 O'Connor Rd, Fairport 14450	28	200	5.0	35	
12	104	Bldg 1,2,3	J-8	Coffee Machine	41 O'Connor Rd, Fairport 14450	108	44	1.0	115	
3	21	Bldg 1,2,3	J-8	Ice Machine	41 O'Connor Rd, Fairport 14450	27	10	1.0	34	

Chain of Custody Sheet	Monroe #1 BOCES Water Testing						EPA Action Level = 1,300 ug/L <	EPA Action Level = 15 ug/L <	Paradigm Report Page #
	Sample ID	Building	Room	Fixture	Address	Count	Result Cooper ug/L	Result Lead ug/L	
12	102	Bldg 1,2,3	J-8	Kitchen Sink near Coffee Station	41 O'Connor Rd, Fairport 14450	106	640	4.4	113
12	103	Bldg 1,2,3	J-8	Sink at Cook Station	41 O'Connor Rd, Fairport 14450	107	770	14.0	114
12	101	Bldg 1,2,3	J-9	Kitchen Sink	41 O'Connor Rd, Fairport 14450	105	810	9.4	112
4	23	Bldg 1,2,3	L-1	Single Kitchen Sink, 1 faucet	41 O'Connor Rd, Fairport 14450	30	210	1.6	37
13	118	Bldg 1,2,3	M-1	Drinking Fountain at Sink	41 O'Connor Rd, Fairport 14450	120	150	1.2	127
13	117	Bldg 1,2,3	M-1	Kitchen Sink	41 O'Connor Rd, Fairport 14450	119	250	1.3	126
12	110	Bldg 1,2,3	M-11	Drinking Fountain at Sink	41 O'Connor Rd, Fairport 14450	114	160	2.4	121
12	109	Bldg 1,2,3	M-11	Kitchen Sink	41 O'Connor Rd, Fairport 14450	113	160	3.1	120
12	108	Bldg 1,2,3	M-12	Drinking Fountain at Sink	41 O'Connor Rd, Fairport 14450	112	180	1.3	119
12	107	Bldg 1,2,3	M-12	Kitchen Sink	41 O'Connor Rd, Fairport 14450	111	190	4.0	118
12	106	Bldg 1,2,3	M-13	Drinking Fountain at Sink	41 O'Connor Rd, Fairport 14450	110	160	1.0	117
12	105	Bldg 1,2,3	M-13	Kitchen Sink	41 O'Connor Rd, Fairport 14450	109	300	1.0	116
9	79	Bldg 1,2,3	M-2	Kitchen Sink, East	41 O'Connor Rd, Fairport 14450	83	170	1.0	90
9	78	Bldg 1,2,3	M-2	Kitchen Sink, south	41 O'Connor Rd, Fairport 14450	82	770	1.8	89
9	80	Bldg 1,2,3	M-2	Utility Sink	41 O'Connor Rd, Fairport 14450	84	230	1.0	91
13	116	Bldg 1,2,3	M-4	Drinking Fountain at Sink	41 O'Connor Rd, Fairport 14450	118	140	1.0	125
13	115	Bldg 1,2,3	M-4	Kitchen Sink	41 O'Connor Rd, Fairport 14450	117	220	1.0	124

Chain of Custody Sheet	Monroe #1 BOCES Water Testing					Paradigm Environmental Services		EPA Action Level = 1,300 ug/L<	EPA Action Level = 15 ug/L<	Paradigm Report Page #
	Sample ID	Building	Room	Fixture	Address	Count	Result Cooper ug/L	Result Lead ug/L		
13	114	Bldg 1,2,3	M-5	NOT SAMPLED Drink Fountain	41 O'Connor Rd, Fairport 14450	116				
13	113	Bldg 1,2,3	M-5	NOT SAMPLED Kitchen Sink	41 O'Connor Rd, Fairport 14450					
13	112	Bldg 1,2,3	M-8	Drinking Fountain at Sink	41 O'Connor Rd, Fairport 14450		190	1.0	123	
13	111	Bldg 1,2,3	M-8	Kitchen Sink	41 O'Connor Rd, Fairport 14450		115	210	1.0	122
13	119	Bldg 1,2,3	M-Hall near M4	Drinking Fountain, Left	41 O'Connor Rd, Fairport 14450		121	62	8.4	128
13	120	Bldg 1,2,3	M-Hall near M4	Drinking Fountain, Right	41 O'Connor Rd, Fairport 14450		122	230	2.4	129
10	84	Bldg 1,2,3	P-1	Drinking Fountain at Sink	41 O'Connor Rd, Fairport 14450		88	220	2.6	95
10	83	Bldg 1,2,3	P-1	Kitchen Sink	41 O'Connor Rd, Fairport 14450		87	260	2.0	94
4	24	Bldg 1,2,3	P-10	Kitchen Sink, 1 faucet, Left	41 O'Connor Rd, Fairport 14450		31	170	1.0	38
10	90	Bldg 1,2,3	P-10	Kitchen Sink, Right	41 O'Connor Rd, Fairport 14450	94	350	1.0	101	
4	25	Bldg 1,2,3	P-14	Single Kitchen Sink, 1 faucet	41 O'Connor Rd, Fairport 14450	32	480	2.1	39	
10	86	Bldg 1,2,3	P-2	Drinking Fountain at Sink	41 O'Connor Rd, Fairport 14450	90	380	4.1	97	
10	85	Bldg 1,2,3	P-2	Kitchen Sink	41 O'Connor Rd, Fairport 14450	89	430	13.0	96	
10	88	Bldg 1,2,3	P-3	Drinking Fountain at Sink	41 O'Connor Rd, Fairport 14450	92	470	1.5	99	
10	87	Bldg 1,2,3	P-3	Kitchen Sink	41 O'Connor Rd, Fairport 14450	91	710	4.3	98	
4	26B	Bldg 1,2,3	P-4G	Single Kitchen sink drinking fountain	41 O'Connor Rd, Fairport 14450	34	130	1.0	41	
4	26A	Bldg 1,2,3	P-4G	Single Kitchen Sink faucet	41 O'Connor Rd, Fairport 14450	33	160	1.0	40	
10	89	Bldg 1,2,3	P-5	Kitchen Sink	41 O'Connor Rd, Fairport 14450	93	190	1.0	100	
4	27	Bldg 1,2,3	Q-10	Single Kitchen Sink 1 faucet, near door	41 O'Connor Rd, Fairport 14450	35	270	1.0	42	
9	77	Bldg 1,2,3	Q-10	Sink near window	41 O'Connor Rd, Fairport 14450	81	280	1.0	88	
4	28	Bldg 1,2,3	Q-4	Single Kitchen Sink, 1 faucet	41 O'Connor Rd, Fairport 14450	36	150	1.0	43	
9	76	Bldg 1,2,3	Q-Hall across Q-11	Drinking Fountain	41 O'Connor Rd, Fairport 14450	80	110	1.7	87	
9	75	Bldg 1,2,3	R-1	Sink	41 O'Connor Rd, Fairport 14450	79	190	3.9	86	
9	74	Bldg 1,2,3	R-25	Sink	41 O'Connor Rd, Fairport 14450	78	220	7.1	85	
9	73	Bldg 1,2,3	R-4	Kitchen Sink	41 O'Connor Rd, Fairport 14450	77	270	3.2	84	
				Sink w/ filtered faucet - sample not through filter						
4	29	Bldg 1,2,3	R-6E		41 O'Connor Rd, Fairport 14450	37	200	1.1	44	
4	30	Bldg 1,2,3	R-Hall outside of R-4	Drinking Fountain	41 O'Connor Rd, Fairport 14450	38	680	2.8	45	
14	121	Bldg 1,2,3	T-5	Kitchen Sink Faucet, Staff Break Rm	41 O'Connor Rd, Fairport 14450	123	160	1.7	130	
4	31	Bldg 1,2,3	U3	Single Kitchen Sink, 1 faucet	41 O'Connor Rd, Fairport 14450	39	150	1.0	46	
5	32	Bldg 1,2,3	U-9D	Single Kitchen Sink, 1 faucet	41 O'Connor Rd, Fairport 14450	40	220	1.5	47	
5	33	Bldg 1,2,3	V-Hall outside of V-8	Drinking Fountain	41 O'Connor Rd, Fairport 14450	41	320	8.8	48	
Bldg 1,2,3 Count		90								
5	35	Bldg 4,5,6	W outside of W-13	Drinking Fountain	38 O'Connor Rd, Fairport 14450	42	300	1.0	49	
5	36	Bldg 4,5,6	W outside of W-5B	Drinking Fountain	38 O'Connor Rd, Fairport 14450	43	420	1.0	50	
5	37	Bldg 4,5,6	X-10	Drinking Fountain	38 O'Connor Rd, Fairport 14450	44	550	8.7	51	
15	131	Bldg 4,5,6	X-10	Sink, Center Faucet	38 O'Connor Rd, Fairport 14450	133	390	51.0	140	
14	130	Bldg 4,5,6	X-10	Sink, Left Faucet	38 O'Connor Rd, Fairport 14450	132	230	36.0	139	
15	132	Bldg 4,5,6	X-10	Sink, Right Faucet	38 O'Connor Rd, Fairport 14450	134	230	17.0	141	
15	134	Bldg 4,5,6	X-9	Sink, Center Faucet	38 O'Connor Rd, Fairport 14450	136	110	7.1	143	
15	133	Bldg 4,5,6	X-9	Sink, Left Faucet	38 O'Connor Rd, Fairport 14450	135	100	8.9	142	
15	135	Bldg 4,5,6	X-9	Sink, Right Faucet	38 O'Connor Rd, Fairport 14450	137	460	32.0	144	
5	38	Bldg 4,5,6	X-Hall outside of X-6	Drinking Fountain	38 O'Connor Rd, Fairport 14450	45	56	1.0	52	

Chain of Custody Sheet	Monroe #1 BOCES Water Testing						EPA Action Level = 1,300 ug/L<	EPA Action Level = 15 ug/L<	Paradigm Report Page #
	Sample ID	Building	Room	Fixture	Address	Count	Result Cooper ug/L	Result Lead ug/L	
14	124	Bldg 4,5,6	Y-11	Sink, Center Faucet	38 O'Connor Rd, Fairport 14450	126	110	16.0	133
14	123	Bldg 4,5,6	Y-11	Sink, Left Faucet	38 O'Connor Rd, Fairport 14450	125	200	34.0	132
14	125	Bldg 4,5,6	Y-11	Sink, Right Faucet	38 O'Connor Rd, Fairport 14450	127	130	16.0	134
5	39	Bldg 4,5,6	Y-2	Laundry sink,	38 O'Connor Rd, Fairport 14450	46	290	6.5	53
5	40	Bldg 4,5,6	Y-8	Drinking Fountain	38 O'Connor Rd, Fairport 14450	47	170	3.5	54
14	129	Bldg 4,5,6	Y-8	Drinking Fountain	38 O'Connor Rd, Fairport 14450	131	96	1.2	138
14	127	Bldg 4,5,6	Y-8	Sink, Center Faucet	38 O'Connor Rd, Fairport 14450	129	210	4.0	136
14	126	Bldg 4,5,6	Y-8	Sink, Left Faucet	38 O'Connor Rd, Fairport 14450	128	480	18.0	135
14	128	Bldg 4,5,6	Y-8	Sink, Right Faucet	38 O'Connor Rd, Fairport 14450	130	96	5.7	137
14	122	Bldg 4,5,6	Y-Hall outside Y-02	Drinking Fountain	38 O'Connor Rd, Fairport 14450	124	190	6.4	131
Bldg 4,5,6 Count		20							
15	136	Bldg 7	J1	Restroom Sink	38 O'Connor Rd, Fairport 14450	138	47	8.0	145
6	42	Bldg 7	J-1	Laundry sink	38 O'Connor Rd, Fairport 14450	48	36	3.3	55
Bldg 7 Count		2							
6	43	Bldg 9,10	A-10	Single Kitchen Sink, 1 faucet	25 O'Connor Rd, Fairport 14450	49	410	2.4	56
6	44	Bldg 9,10	A-4	Single Kitchen Sink, 1 faucet	25 O'Connor Rd, Fairport 14450	50	280	14.0	57
15	138	Bldg 9,10	A-5	Kitchen Sink	25 O'Connor Rd, Fairport 14450	140	90	1.0	147
6	45	Bldg 9,10	A-7	Single Kitchen Sink, 1 faucet	25 O'Connor Rd, Fairport 14450	51	260	1.1	58
6	47	Bldg 9,10	A-9	Single Kitchen Sink, 1 faucet	25 O'Connor Rd, Fairport 14450	52	480	11.0	59
6	48	Bldg 9,10	A-Hall outside of A-6	Drinking Fountain	25 O'Connor Rd, Fairport 14450	53	750	1.0	60
6	49	Bldg 9,10	B-7	Single Kitchen Sink, 1 faucet	25 O'Connor Rd, Fairport 14450	54	710	2.7	61

Chain of Custody Sheet	Monroe #1 BOCES Water Testing					Paradigm Environmental Services		EPA Action Level = 1,300 ug/L<	EPA Action Level = 15 ug/L<	Paradigm Report Page #
	Sample ID	Building	Room	Fixture	Address	Count	Result Cooper ug/L	Result Lead ug/L		
6	50	Bldg 9,10	B-Hall outside of B-1	Drinking Fountain	25 O'Connor Rd, Fairport 14450	55	210	1.0	62	
7	53	Bldg 9,10	C-3B	Single Kitchen Sink, 1 faucet	25 O'Connor Rd, Fairport 14450	56	110	9.4	63	
16	142	Bldg 9,10	C-3B1	Kitchen Sink, Left	25 O'Connor Rd, Fairport 14450	144	470	2.2	151	
16	143	Bldg 9,10	C-3B1	Kitchen Sink, Right	25 O'Connor Rd, Fairport 14450	145	440	1.7	152	
7	54	Bldg 9,10	C-6	Single Kitchen Sink, 1 faucet	25 O'Connor Rd, Fairport 14450	57	260	1.0	64	
7	57B	Bldg 9,10	D-10	3 Bay Sink, Faucet Left	25 O'Connor Rd, Fairport 14450	61	510	11.0	68	
7	57A	Bldg 9,10	D-10	3 Bay Sink, Faucet Right	25 O'Connor Rd, Fairport 14450	60	720	13.0	67	
7	56	Bldg 9,10	D-10	Ice maker	25 O'Connor Rd, Fairport 14450	59	10	1.0	66	
7	58	Bldg 9,10	D-3	Single Kitchen Sink, 1 faucet	25 O'Connor Rd, Fairport 14450	62	460	23.0	69	
7	59	Bldg 9,10	D-8	Single Kitchen Sink, 1 faucet	25 O'Connor Rd, Fairport 14450	63	110	10.0	70	
7	55	Bldg 9,10	E-Hall	Drinking Fountain	25 O'Connor Rd, Fairport 14450	58	120	1.0	65	
7	60	Bldg 9,10	F-1	Single Kitchen Sink, 1 faucet	25 O'Connor Rd, Fairport 14450	64	440	31.0	71	
8	61	Bldg 9,10	F-5	Single Kitchen Sink, 1 faucet	25 O'Connor Rd, Fairport 14450	65	180	1.4	72	
8	62	Bldg 9,10	F-6	Single Kitchen Sink, 1 faucet	25 O'Connor Rd, Fairport 14450	66	300	1.1	73	
8	63	Bldg 9,10	F-Hall outside of F-3	Drinking Fountain	25 O'Connor Rd, Fairport 14450	67	420	1.0	74	
Bldg 9,10 Count		22								
8	64	Harris	A-2	Single Kitchen Sink, 1 faucet	2596 Barid Rd, Penfield 14526	68	46	1.0	75	
8	65	Harris	B-Hall outside of B-7	Drinking Fountain	2596 Barid Rd, Penfield 14526	69	40	1.0	76	
Harris Count		2								
8	66	Linden Park 11	A-12	Single Kitchen Sink, 1 faucet	11 Linden Pk, Rochester 14625	70	210	1.2	77	
16	139	Linden Park 11	C-Hall outside C-10	Drinking Fountain	11 Linden Pk, Rochester 14625	141	240	1.0	148	
8	67	Linden Park 11	C-Hall outside C-10	Drinking Fountain, Left	11 Linden Pk, Rochester 14625	71	210	1.0	78	
Linden Park 11		3								
8	68	Linden Park 15	B-12	Single Kitchen Sink, 1 faucet	15 Linden Pk, Rochester 14625	72	170	1.8	79	
16	140	Linden Park 15	B-12?	Coffee Maker	15 Linden Pk, Rochester 14625	142	130	1.1	149	
8	69	Linden Park 15	C-Hall outside of C-4	Drinking Fountain	15 Linden Pk, Rochester 14625	73	840	1.0	80	
8	70	Linden Park 15	D-8	Single Kitchen Sink, 1 faucet	15 Linden Pk, Rochester 14625	74	720	4.8	81	
Linden Park 15		4								
3	20	NOT USED								
5	34	NOT USED								
5	41	NOT USED								
6	46	NOT USED								
6	51	NOT USED								
7	52	NOT USED								
NOT USED Count		6								
15	137	Transportation	T-02A	Bottle Filling Station	79 O'Connor Rd, Fariport 14450	139	520	1.0	146	
9	72	Transportation	T-02A	Drinking and Bottle Filling Fountain	79 O'Connor Rd, Fariport 14450	76	700	1.0	83	
9	71	Transportation	T-02A	Kitchen Sink	79 O'Connor Rd, Fariport 14450	75	70	1.0	82	
Transportation Count		3								
Grand Count		152								

Chain of Custody Sheet	Monroe #1 BOCES Water Testing						EPA Action Level = 1,300 ug/L<	EPA Action Level = 15 ug/L<	Paradigm Report Page #		
	Sample ID	Building	Room	Fixture	Address	Count	Result Cooper ug/L	Result Lead ug/L			
Chain of Custody Sheet	Monroe #1 BOCES Water Testing by Paradigm Environmental Svcs, Inc.			Sampled 09/20/2016, Analyzed 10/6/2016, Reported 10/07/2016			EPA Action Level = 1,300 ug/L<	EPA Action Level = 15 ug/L<	Paradigm Report Page #	Work order for "DO NOT DRINK" sign	Work order for piping remediation
	Sample ID 420-110628-	Building	Room	Fixture	Address	Count	Result Cooper ug/L	Result Lead ug/L			
1	2	Bldg 9,10	D-03		25 O'Connor Rd	2		16.5	6	44909	44916
1	3	Bldg 9,10	D-10A		25 O'Connor Rd	3		1.0	7		
1	4	Bldg 9,10	D-10B		25 O'Connor Rd	4		1.0	8		
1	5	Bldg 9,10	F-1	Single Kitchen Sink, 1 faucet	25 O'Connor Rd	5		66.0	9	44911	44917
1	6	Bldg 9,10	A-04		25 O'Connor Rd	6		1.0	10		
1	7	Bldg 9,10	A-09		25 O'Connor Rd	7		8.0	11		
1	8	Bldg 4,5,6	X-09A		38 O'Connor Rd	8		2.6	12		
1	9	Bldg 4,5,6	X-09B		38 O'Connor Rd	9		3.1	13		
1	10	Bldg 4,5,6	X-09C		38 O'Connor Rd	10		1.0	14		
2	11	Bldg 4,5,6	X-10A*		38 O'Connor Rd	11		31.0	15	44906	44914
2	12	Bldg 4,5,6	X-10B		38 O'Connor Rd	12		5.5	16		
2	13	Bldg 4,5,6	X-10C		38 O'Connor Rd	13		2.7	17		
2	14	Bldg 4,5,6	Y-11A		38 O'Connor Rd	14		23.6	18	44907	44915
2	15	Bldg 4,5,6	Y-11B		38 O'Connor Rd	15		5.3	19		
2	16	Bldg 4,5,6	Y-11C		38 O'Connor Rd	16		8.6	20		
2	17	Bldg 4,5,6	Y-08A		38 O'Connor Rd	17		5.2	21		
2	18	Bldg 4,5,6	Y-08B		38 O'Connor Rd	18		6.2	22		
2	19	Bldg 4,5,6	Y-08C		38 O'Connor Rd	19		5.1	23		
2	20	Bldg 1,2,3	J-17L		41 O'Connor Rd	20		1.0	24		
1	1	Bldg 1,2,3	J-08	Main Kitchen Hand washing sink	41 O'Connor Rd	1		1.8	5		
1	21	Bldg 1,2,3	P-02		41 O'Connor Rd	21		17.0	25	44905	44913

*A is left faucet, B is center faucet on triple faucet sinks and the right faucet on dual faucet sinks, and C is the right faucet on triple faucet sinks.