

Monroe One BOCES Bird Morgan School 108-120 East Ave, East Rochester, NY 14445					EPA Action Level > 15 ug/L	Lab Sample ID 420-168095-xx	Report Page #	Testing Date: February 18, 2020	Notes	Count
Building	Bldg Area	Room	Chain of Custody Sample Number	Fixture	Result Lead ug/L			Time Sampled		
Bird Morgan	1	A105A Main Office	1	Office Sink	1.00	1	6 of 62	6:59 AM		1
Bird Morgan	1	B104	2	Classroom Sink	1.14	2	7 of 62	7:01 AM		2
Bird Morgan	1	B109	3	Classroom Sink	1.39	3	8 of 62	7:06 AM		3
Bird Morgan	1	B110	4	Classroom Sink	11.80	4	9 of 62	7:05 AM		4
Bird Morgan	1	B111 (Vacant)	5	Classroom Sink						
Bird Morgan	1	B112 (B102) Nurse	6	Nurse Sink at Entry	1.13	5	10 of 62	7:10 AM		5
Bird Morgan	1	B115 Hall	7	Drinking Fountain	1.00	6	11 of 62	7:07 AM		6
Bird Morgan	1	B116	8	Classroom Sink	2.69	7	12 of 62	7:06 AM		7
Bird Morgan	1	M104	9	Classroom Sink	1.00	8	13 of 62	7:12 AM		8
Bird Morgan	1	M109	10	Classroom Sink	1.00	9	14 of 62	7:23 AM		9
Bird Morgan	1	M116	11	Science Lab Sink	2.04	10	15 of 62	7:26 AM		10
Bird Morgan	Grd	M011	12	Classroom Sink Left HC	18.30	11	16 of 62	8:20 AM	1	11
Bird Morgan			13							
Bird Morgan			14							
Bird Morgan	2	B201	15	Classroom Sink	1.00	12	17 of 62	7:48 AM		12
Bird Morgan	2	B204	16	Classroom Sink	1.00	13	18 of 62	7:49 AM		13
Bird Morgan	2	B208	17	Classroom Sink	1.26	14	19 of 62	7:55 AM		14
Bird Morgan	2	B209	18	Classroom Sink	4.52	15	20 of 62	7:54 AM		15
Bird Morgan			19							
Bird Morgan	2	G Hall outside B211E	20	Drinking Fountain East	1.00	16	21 of 62	7:53 AM		16
Bird Morgan	2	M204	21	Classroom Sink	1.00	17	22 of 62	7:41 AM		17
Bird Morgan			22							
Bird Morgan	2	M209	23	Classroom Sink	1.00	18	23 of 62	7:38 AM		18
Bird Morgan	2	M218A	24	Classroom Sink	1.00	19	24 of 62	7:33 AM		19
Bird Morgan	2	U Hall outside M205	25	Drinking Fountain	7.05	20	25 of 62	7:40 AM		20
Bird Morgan	2	V Hall outside M241	26	Drinking Fountain	1.00	21	26 of 62	7:39 AM		21
Bird Morgan	2	W Hall outside M210	27	Drinking Fountain	1.00	22	27 of 62	7:37 AM		22
Bird Morgan	Grd	A Hall by A003	28	Drinking Fountain, Reg	1.00	23	28 of 62	8:12 AM		23
Bird Morgan	Grd	A Hall outside B010	30	Drinking Fountain	1.00	24	29 of 62	8:06 AM		24
Bird Morgan	Grd	B010 Life Skills	34	Kitchen Sink	1.00	25	30 of 62	8:05 AM		25
Bird Morgan	Grd	B003 3 Bay Sink	35	Dish Station Sink	2.43	26	31 of 62	8:08 AM		26
Bird Morgan	Grd	M016A Laundry Rm	36	Kitchen Sink	1.00	27	32 of 62	8:26 AM		27
Bird Morgan	Grd	B003 Food Prep	37	Single Bay Sink	7.66	28	33 of 62	8:09 AM		28
Bird Morgan	Grd	A005 Serving Line	38	Single Bay Sink	18.40	29	34 of 62	8:10 AM	1	29
Bird Morgan	Grd	L Hall outside M010	39	Drinking Fountain	1.00	30	35 of 62	8:22 AM		30
Bird Morgan	Grd	M Hall outside MT02	40	Drinking Fountain	1.00	31	36 of 62	8:16 AM		31
Bird Morgan			41							
Bird Morgan	Grd	M009	42	Classroom Sink	1.00	32	37 of 62	8:18 AM		32
Bird Morgan	Grd	M011	43	Classroom Sink Right	6.41	33	38 of 62	8:20 AM		33
Bird Morgan	Grd	M016 by Windows	44	Staff Lounge Sink	1.89	34	39 of 62	8:25 AM		34
Bird Morgan	Grd	M016 toward Hall	45	Staff Lounge Sink	67.90	35	40 of 62	8:25 AM	1	35
Bird Morgan	Grd	M019	46	Art Lab Sink	1.43	36	41 of 62	8:27 AM		36
Bird Morgan	Grd	N Hall outside M016	47	Drinking Fountain	1.03	37	42 of 62	8:28 AM		37
Bird Morgan	1	B112 (B102) Nurse	48	Nurse Sink Exam Side	1.00	38	43 of 62	7:10 AM		38
Bird Morgan	1	A105B Conference Rm	49	Kitchen Sink	1.00	39	44 of 62	7:15 AM		39
Bird Morgan	1	M Hall by M106	50	Drinking Fountain	1.49	40	45 of 62	7:19 AM		40
Bird Morgan	1	M Hall by M110	51	Drinking Fountain	1.00	41	46 of 62	7:22 AM		41
Bird Morgan	Grd	A Hall outside A003	52	Drinking Fountain, HC	1.00	42	47 of 62	8:12 AM		42
Bird Morgan	2	H Hall across B211W	53	Drinking Fountain	1.00	43	48 of 62	7:51 AM		43

Bird Morgan School Testing February 25, 2020								2/25/2020	
Bird Morgan	Grd	A Hall outside B008	29	Drinking Fountain	ND	1	3 of 3	6:54 AM	44
Bird Morgan	Grd	B006	31	Classroom Sink	ND	2	3 of 3	6:58 AM	45
Bird Morgan	Grd	B008	32	Storage Area Sink	0.0017	3	3 of 3	6:55 AM	46
Bird Morgan	Grd	B009	33	Classroom Sink	0.0024	4	3 of 3	6:56 AM	47

Note1 Outlet shut off, then faucet replaced. Outlet to be retested

Results posted <https://www.monroe.edu/Domain/1516>

Lab results 3/9/2020

Bird Morgan School Re-Test February 04, 2021								
Bird Morgan	Grd	A005 Serving Line	210473-01	Single Bay Sink	< 1 ug/L	210473-01	2 of 9	6:33 AM
Bird Morgan	Grd	M011	210473-02	Classroom Sink Left HC	< 1 ug/L	210473-02	3 of 9	6:35 AM
Bird Morgan	Grd	M016 toward Hall	210473-03	Staff Lounge Sink	< 1 ug/L	210473-03	4 of 9	6:42 AM

1 mg/L = 1000 ug/L

Lab results of 2/8/2021 received 02/09/2021