

Site Radon Inspection Report

Date : 12/15/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Foreman Center Bldg 1
Test Location: 41 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2353070 Test Start : 12/09/2014 @ 09:34
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:38
Location : First Floor-E2C Received: 12/15/2014 @ 16:00
Radon Level : 0.3 pCi/L Analyzed: 12/17/2014 @ 16:46
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2353074 Test Start : 12/09/2014 @ 10:45
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:23
Location : First Floor-C14 Received: 12/15/2014 @ 16:00
Radon Level : 0.3 pCi/L Analyzed: 12/17/2014 @ 15:57
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2353075 Test Start : 12/09/2014 @ 10:35
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:12
Location : First Floor-C9H Received: 12/15/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 14:20
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2353076 Test Start : 12/09/2014 @ 09:49
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:46
Location : First Floor-A8 Received: 12/16/2014 @ 09:00
Radon Level : 0.5 pCi/L Analyzed: 12/17/2014 @ 14:06
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2353078 Test Start : 12/09/2014 @ 10:18
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:03
Location : First Floor-B14-Off Received: 12/16/2014 @ 11:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 16:15
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2353083 Test Start : 12/09/2014 @ 10:41
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:18
Location : First Floor-C11A Received: 12/15/2014 @ 16:00
Radon Level : 0.6 pCi/L Analyzed: 12/18/2014 @ 11:13
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/15/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Foreman Center Bldg 1
Test Location: 41 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2353084 Test Start : 12/09/2014 @ 10:51
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:25
Location : First Floor-C11A Received: 12/15/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 14:20
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2353095 Test Start : 12/09/2014 @ 10:24
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:06
Location : First Floor-C3A Received: 12/15/2014 @ 15:00
Radon Level : 0.3 pCi/L Analyzed: 12/17/2014 @ 14:20
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2353107 Test Start : 12/09/2014 @ 09:20
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:34
Location : First Floor-E5 Received: 12/16/2014 @ 09:00
Radon Level : 0.5 pCi/L Analyzed: 12/17/2014 @ 16:15
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2353116 Test Start : 12/09/2014 @ 10:50
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:25
Location : First Floor-C11C Received: 12/15/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 14:38
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2353117 Test Start : 12/09/2014 @ 10:45
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:23
Location : First Floor-C14C Received: 12/15/2014 @ 16:00
Radon Level : 0.3 pCi/L Analyzed: 12/17/2014 @ 13:30
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2353118 Test Start : 12/09/2014 @ 10:37
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:12
Location : First Floor-C9C Received: 12/15/2014 @ 16:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 16:31
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/15/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Foreman Center Bldg 1
Test Location: 41 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2353119 Test Start : 12/09/2014 @ 10:47
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:23
Location : First Floor-C14 D Rm Received: 12/15/2014 @ 16:00
Radon Level : 0.3 pCi/L Analyzed: 12/17/2014 @ 15:22
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2353121 Test Start : 12/09/2014 @ 10:25
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:06
Location : First Floor-C3C Received: 12/15/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 14:20
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2353122 Test Start : 12/09/2014 @ 09:22
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:35
Location : First Floor-E5G Received: 12/15/2014 @ 16:00
Radon Level : 0.3 pCi/L Analyzed: 12/17/2014 @ 16:31
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2353136 Test Start : 12/09/2014 @ 10:34
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:11
Location : First Floor-C9A Received: 12/16/2014 @ 09:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 16:46
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2353137 Test Start : 12/09/2014 @ 10:16
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:02
Location : First Floor-B12 Received: 12/16/2014 @ 09:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 16:15
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2353138 Test Start : 12/09/2014 @ 10:59
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:28
Location : First Floor-D8 Received: 12/16/2014 @ 09:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 16:46

Radon concentration is estimated due to missing stop time.

Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Foreman Center Bldg 1
Test Location: 41 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2353139 Test Start : 12/09/2014 @ 10:43
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:19
Location : First Floor-C11 Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 12:26
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2353140 Test Start : 12/09/2014 @ 10:24
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:06
Location : First Floor-C3B Received: 12/15/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 13:30
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2353141 Test Start : 12/09/2014 @ 10:42
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:18
Location : First Floor-C11B Received: 12/16/2014 @ 09:00
Radon Level : 0.2 pCi/L Analyzed: 12/17/2014 @ 16:46
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2353143 Test Start : 12/09/2014 @ 09:18
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:32
Location : First Floor-E2 Received: 12/16/2014 @ 09:00
Radon Level : 0.6 pCi/L Analyzed: 12/17/2014 @ 15:57
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2353146 Test Start : 12/09/2014 @ 09:20
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:34
Location : First Floor-E5C Received: 12/16/2014 @ 09:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 16:15
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2353154 Test Start : 12/09/2014 @ 10:36
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:12
Location : First Floor-C9E Received: 12/15/2014 @ 15:00
Radon Level : 1.2 pCi/L Analyzed: 12/18/2014 @ 11:13
Error for Measurement is: ± 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/15/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Foreman Center Bldg 1
Test Location: 41 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2353155 Test Start : 12/09/2014 @ 10:27
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:07
Location : First Floor-D15E Received: 12/15/2014 @ 15:00
Radon Level : 0.4 pCi/L Analyzed: 12/17/2014 @ 15:22
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2353156 Test Start : 12/09/2014 @ 10:26
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:07
Location : First Floor-C4 Received: 12/15/2014 @ 15:00
Radon Level : 0.4 pCi/L Analyzed: 12/17/2014 @ 14:20
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2353161 Test Start : 12/09/2014 @ 10:35
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:12
Location : First Floor-C9G Received: 12/15/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 13:48
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2353162 Test Start : 12/09/2014 @ 10:44
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:23
Location : First Floor-C14A Received: 12/16/2014 @ 09:00
Radon Level : 0.2 pCi/L Analyzed: 12/17/2014 @ 16:32
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2353163 Test Start : 12/09/2014 @ 10:22
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:04
Location : First Floor-B14-Rest R Received: 12/15/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 13:30
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2353167 Test Start : 12/09/2014 @ 09:19
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:34
Location : First Floor-E5B Received: 12/16/2014 @ 11:00
Radon Level : 0.4 pCi/L Analyzed: 12/16/2014 @ 12:26
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Foreman Center Bldg 1
Test Location: 41 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2353169 Test Start : 12/09/2014 @ 09:33
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:37
Location : First Floor-E2A Received: 12/16/2014 @ 09:00
Radon Level : 0.5 pCi/L Analyzed: 12/17/2014 @ 16:15
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2353170 Test Start : 12/09/2014 @ 10:52
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:25
Location : First Floor-C11E Received: 12/15/2014 @ 15:00
Radon Level : 0.2 pCi/L Analyzed: 12/17/2014 @ 16:46
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2353171 Test Start : 12/09/2014 @ 09:45
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:44
Location : First Floor-D5 Received: 12/16/2014 @ 09:00
Radon Level : 0.4 pCi/L Analyzed: 12/17/2014 @ 16:32
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2353172 Test Start : 12/09/2014 @ 10:34
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:11
Location : First Floor-C9B Received: 12/15/2014 @ 16:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 14:57
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2353173 Test Start : 12/09/2014 @ 10:32
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:10
Location : First Floor-C9J Received: 12/16/2014 @ 09:00
Radon Level : 0.2 pCi/L Analyzed: 12/17/2014 @ 16:15
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2353180 Test Start : 12/09/2014 @ 10:52
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:25
Location : First Floor-C11E Received: 12/15/2014 @ 15:00
Radon Level : 0.4 pCi/L Analyzed: 12/18/2014 @ 11:13
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/15/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Foreman Center Bldg 1
Test Location: 41 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2353181 Test Start : 12/09/2014 @ 10:29
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:09
Location : First Floor-C5 Received: 12/15/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 13:30
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2353182 Test Start : 12/09/2014 @ 10:30
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:09
Location : First Floor-D15A Received: 12/15/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 13:14
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2353183 Test Start : 12/09/2014 @ 09:44
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:43
Location : First Floor-D4A-Sm Received: 12/15/2014 @ 16:00
Radon Level : 0.4 pCi/L Analyzed: 12/17/2014 @ 16:32
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2353185 Test Start : 12/09/2014 @ 09:20
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:34
Location : First Floor-E5D Received: 12/16/2014 @ 09:00
Radon Level : 0.7 pCi/L Analyzed: 12/17/2014 @ 16:15
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2353188 Test Start : 12/09/2014 @ 10:48
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:25
Location : First Floor-C11D Received: 12/15/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 14:38
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2353189 Test Start : 12/09/2014 @ 09:21
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:35
Location : First Floor-E5E Received: 12/16/2014 @ 09:00
Radon Level : 0.7 pCi/L Analyzed: 12/17/2014 @ 16:46
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Foreman Center Bldg 1
Test Location: 41 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2353192 Test Start : 12/09/2014 @ 09:46
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:44
Location : First Floor-D5A Received: 12/16/2014 @ 09:00
Radon Level : 0.4 pCi/L Analyzed: 12/17/2014 @ 15:57
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2353193 Test Start : 12/09/2014 @ 10:17
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:02
Location : First Floor-B14-Off Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 12:26
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2353201 Test Start : 12/09/2014 @ 10:44
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:23
Location : First Floor-C11D Received: 12/15/2014 @ 16:00
Radon Level : 0.2 pCi/L Analyzed: 12/17/2014 @ 16:46
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2353207 Test Start : 12/09/2014 @ 10:30
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:09
Location : First Floor-D15D Received: 12/15/2014 @ 15:00
Radon Level : 0.4 pCi/L Analyzed: 12/17/2014 @ 13:30
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2353214 Test Start : 12/09/2014 @ 09:47
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:45
Location : First Floor-D7 Received: 12/16/2014 @ 09:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 16:15
Error for Measurement is: \pm 0.9 pCi/L

Canister ID# : 2353219 Test Start : 12/09/2014 @ 09:21
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:35
Location : First Floor-E5E Received: 12/16/2014 @ 09:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 16:32
Error for Measurement is: \pm 0.3 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Foreman Center Bldg 1
Test Location: 41 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2353220 Test Start : 12/09/2014 @ 10:34
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:11
Location : First Floor-C9B Received: 12/16/2014 @ 09:00
Radon Level : 0.2 pCi/L Analyzed: 12/17/2014 @ 16:15
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2353221 Test Start : 12/09/2014 @ 10:36
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:12
Location : First Floor-C9F Received: 12/15/2014 @ 15:01
Radon Level : 0.2 pCi/L Analyzed: 12/17/2014 @ 14:06
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2353230 Test Start : 12/09/2014 @ 10:43
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:19
Location : First Floor-C11 Received: 12/16/2014 @ 09:00
Radon Level : 0.4 pCi/L Analyzed: 12/17/2014 @ 14:06
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2353232 Test Start : 12/09/2014 @ 10:26
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:07
Location : First Floor-C4 Received: 12/15/2014 @ 16:00
Radon Level : 0.7 pCi/L Analyzed: 12/17/2014 @ 14:20
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2353234 Test Start : 12/09/2014 @ 10:19
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:03
Location : First Floor-B14 Received: 12/15/2014 @ 16:00
Radon Level : 0.2 pCi/L Analyzed: 12/17/2014 @ 15:22
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2353237 Test Start : 12/09/2014 @ 09:48
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:45
Location : First Floor-D7 Received: 12/15/2014 @ 16:00
Radon Level : 0.8 pCi/L Analyzed: 12/17/2014 @ 16:46
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Foreman Center Bldg 1
Test Location: 41 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2361634 Test Start : 12/09/2014 @ 10:02
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:54
Location : First Floor-B5 Received: 12/16/2014 @ 09:00
Radon Level : 0.5 pCi/L Analyzed: 12/17/2014 @ 16:32
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361638 Test Start : 12/09/2014 @ 10:37
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:12
Location : First Floor-C9D Received: 12/16/2014 @ 09:00
Radon Level : 0.4 pCi/L Analyzed: 12/17/2014 @ 16:15
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361642 Test Start : 12/09/2014 @ 09:24
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:36
Location : First Floor-E3A Received: 12/16/2014 @ 09:00
Radon Level : 0.2 pCi/L Analyzed: 12/17/2014 @ 16:46
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361643 Test Start : 12/09/2014 @ 09:41
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:43
Location : First Floor-D4C Received: 12/16/2014 @ 09:00
Radon Level : 0.5 pCi/L Analyzed: 12/17/2014 @ 16:32
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2361687 Test Start : 12/09/2014 @ 10:04
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:54
Location : First Floor-B1 Received: 12/15/2014 @ 16:00
Radon Level : 0.4 pCi/L Analyzed: 12/17/2014 @ 14:06
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2361706 Test Start : 12/09/2014 @ 10:33
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:10
Location : First Floor-C9I Received: 12/15/2014 @ 15:00
Radon Level : 0.6 pCi/L Analyzed: 12/17/2014 @ 16:46
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Foreman Center Bldg 1
Test Location: 41 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2361710 Test Start : 12/09/2014 @ 09:43
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:43
Location : First Floor-D4A Received: 12/16/2014 @ 09:00
Radon Level : 1.1 pCi/L Analyzed: 12/17/2014 @ 16:15
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361711 Test Start : 12/09/2014 @ 09:33
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:37
Location : First Floor-E2 Received: 12/15/2014 @ 16:00
Radon Level : 1.2 pCi/L Analyzed: 12/17/2014 @ 16:46
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361716 Test Start : 12/09/2014 @ 10:14
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:59
Location : First Floor-B9-Off Received: 12/15/2014 @ 16:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 13:30
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2361717 Test Start : 12/09/2014 @ 10:04
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:55
Location : First Floor-B2/B3 Received: 12/15/2014 @ 16:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 15:22
Error for Measurement is: \pm 0.9 pCi/L

Canister ID# : 2361719 Test Start : 12/09/2014 @ 10:15
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:00
Location : First Floor-B11 Received: 12/15/2014 @ 16:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 13:48
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361720 Test Start : 12/09/2014 @ 10:58
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:28
Location : First Floor-D8 Received: 12/15/2014 @ 15:00
Radon Level : 0.3 pCi/L Analyzed: 12/17/2014 @ 14:38
Radon concentration is estimated due to missing stop time.

Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/15/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Foreman Center Bldg 1
Test Location: 41 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2361721 Test Start : 12/09/2014 @ 10:49
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:25
Location : First Floor-C11B Received: 12/15/2014 @ 16:00
Radon Level : 0.2 pCi/L Analyzed: 12/17/2014 @ 14:20
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361722 Test Start : 12/09/2014 @ 10:12
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:56
Location : First Floor-B7Rear Received: 12/15/2014 @ 16:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 14:38
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361725 Test Start : 12/09/2014 @ 10:25
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:06
Location : First Floor-C3D Received: 12/15/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 13:14
Error for Measurement is: \pm 0.1 pCi/L

Canister ID# : 2361726 Test Start : 12/09/2014 @ 09:35
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:38
Location : First Floor-E1C Received: 12/16/2014 @ 09:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 16:15
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2361728 Test Start : 12/09/2014 @ 10:13
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:58
Location : First Floor-B10-Storage Received: 12/16/2014 @ 09:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 16:46
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361729 Test Start : 12/09/2014 @ 09:35
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:39
Location : First Floor-E1D Received: 12/15/2014 @ 16:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 16:46
Error for Measurement is: \pm 0.3 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/15/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Foreman Center Bldg 1
Test Location: 41 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2361732 Test Start : 12/09/2014 @ 09:44
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:43
Location : First Floor-D4A-Sm Received: 12/15/2014 @ 16:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 16:46
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361734 Test Start : 12/09/2014 @ 10:14
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:59
Location : First Floor-B9 Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 12:26
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2361735 Test Start : 12/09/2014 @ 10:12
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:56
Location : First Floor-B7 Front Received: 12/16/2014 @ 09:00
Radon Level : 0.4 pCi/L Analyzed: 12/17/2014 @ 16:32
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361736 Test Start : 12/09/2014 @ 10:05
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:56
Location : First Floor-A2 Received: 12/15/2014 @ 16:00
Radon Level : 0.8 pCi/L Analyzed: 12/17/2014 @ 16:32
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361737 Test Start : 12/09/2014 @ 10:54
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:26
Location : First Floor-D13B Received: 12/15/2014 @ 15:00
Radon Level : 0.3 pCi/L Analyzed: 12/17/2014 @ 14:57
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361738 Test Start : 12/09/2014 @ 09:34
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:38
Location : First Floor-E2C Received: 12/15/2014 @ 16:00
Radon Level : 0.2 pCi/L Analyzed: 12/17/2014 @ 16:46
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/15/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Foreman Center Bldg 1
Test Location: 41 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2361768 Test Start : 12/09/2014 @ 10:13
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:57
Location : First Floor-Store Received: 12/15/2014 @ 16:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 16:32
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2361772 Test Start : 12/09/2014 @ 09:55
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:49
Location : First Floor-C6H Received: 12/16/2014 @ 09:00
Radon Level : 0.4 pCi/L Analyzed: 12/17/2014 @ 16:15
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361773 Test Start : 12/09/2014 @ 11:00
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:28
Location : First Floor-D8 Received: 12/15/2014 @ 15:00
Radon Level : 0.2 pCi/L Analyzed: 12/17/2014 @ 14:38
Radon concentration is estimated due to missing stop time.

Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361774 Test Start : 12/09/2014 @ 09:50
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:44
Location : First Floor-A7 Received: 12/16/2014 @ 09:00
Radon Level : 0.2 pCi/L Analyzed: 12/17/2014 @ 16:32
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2361775 Test Start : 12/09/2014 @ 09:42
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:43
Location : First Floor-Maint Received: 12/16/2014 @ 12:00
Radon Level : 0.2 pCi/L Analyzed: 12/16/2014 @ 12:26
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2361776 Test Start : 12/09/2014 @ 09:35
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:39
Location : First Floor-E1B Received: 12/16/2014 @ 12:00
Radon Level : 0.2 pCi/L Analyzed: 12/16/2014 @ 12:26
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/15/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Foreman Center Bldg 1
Test Location: 41 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2361777 Test Start : 12/09/2014 @ 10:57
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:26
Location : First Floor-D10 Received: 12/15/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 13:30
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2361778 Test Start : 12/09/2014 @ 10:16
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:02
Location : First Floor-B12 Received: 12/16/2014 @ 09:00
Radon Level : 0.3 pCi/L Analyzed: 12/17/2014 @ 15:57
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2361782 Test Start : 12/09/2014 @ 10:40
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:13
Location : First Floor-D14B-Fac Rm Received: 12/15/2014 @ 15:00
Radon Level : 0.2 pCi/L Analyzed: 12/17/2014 @ 14:20
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361792 Test Start : 12/09/2014 @ 10:18
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:03
Location : First Floor-B14-Off Received: 12/16/2014 @ 09:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 16:32
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361793 Test Start : 12/09/2014 @ 09:19
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:34
Location : First Floor-E5A Received: 12/15/2014 @ 16:00
Radon Level : 0.8 pCi/L Analyzed: 12/18/2014 @ 11:13
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361795 Test Start : 12/09/2014 @ 09:24
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:36
Location : First Floor-E3 Received: 12/16/2014 @ 11:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 14:06
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Foreman Center Bldg 1
Test Location: 41 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2361796 Test Start : 12/09/2014 @ 09:39
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:41
Location : First Floor-D2 Received: 12/16/2014 @ 12:00
Radon Level : 0.5 pCi/L Analyzed: 12/16/2014 @ 12:26
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2361797 Test Start : 12/09/2014 @ 09:25
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:36
Location : First Floor-E4 Received: 12/15/2014 @ 16:00
Radon Level : 0.2 pCi/L Analyzed: 12/17/2014 @ 16:31
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361798 Test Start : 12/09/2014 @ 09:36
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:39
Location : First Floor-E1F Received: 12/16/2014 @ 09:00
Radon Level : 0.7 pCi/L Analyzed: 12/17/2014 @ 16:15
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361807 Test Start : 12/09/2014 @ 09:21
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:35
Location : First Floor-E5F Received: 12/16/2014 @ 09:00
Radon Level : 0.2 pCi/L Analyzed: 12/17/2014 @ 14:57
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2361808 Test Start : 12/09/2014 @ 10:28
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:08
Location : First Floor-D15G Received: 12/15/2014 @ 15:00
Radon Level : 0.2 pCi/L Analyzed: 12/17/2014 @ 13:48
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2361809 Test Start : 12/09/2014 @ 09:53
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:49
Location : First Floor-C6G Received: 12/16/2014 @ 09:00
Radon Level : 0.2 pCi/L Analyzed: 12/17/2014 @ 14:38
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Foreman Center Bldg 1
Test Location: 41 O'Connor Road
Fairport, NY 14450-
Individual Canister Results

Canister ID# : 2361810 Test Start : 12/09/2014 @ 09:55
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:49
Location : First Floor-C6B Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 12:26
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361811 Test Start : 12/09/2014 @ 09:39
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:41
Location : First Floor-D5B Received: 12/15/2014 @ 16:00
Radon Level : 0.8 pCi/L Analyzed: 12/18/2014 @ 11:13
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361812 Test Start : 12/09/2014 @ 10:13
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:58
Location : First Floor-B10-Frt Received: 12/15/2014 @ 16:01
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 13:48
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2361813 Test Start : 12/09/2014 @ 09:58
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:53
Location : First Floor-A5 Stor Received: 12/16/2014 @ 09:00
Radon Level : 0.6 pCi/L Analyzed: 12/17/2014 @ 15:57
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361814 Test Start : 12/09/2014 @ 09:55
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:49
Location : First Floor-C61 Received: 12/16/2014 @ 11:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 12:26
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361815 Test Start : 12/09/2014 @ 09:57
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:52
Location : First Floor-A5 Received: 12/16/2014 @ 09:00
Radon Level : 0.5 pCi/L Analyzed: 12/17/2014 @ 16:15
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Foreman Center Bldg 1
Test Location: 41 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2361816 Test Start : 12/09/2014 @ 09:52
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:48
Location : First Floor-C6D Received: 12/16/2014 @ 09:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 16:46
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2361819 Test Start : 12/09/2014 @ 09:55
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:49
Location : First Floor-C6A Received: 12/16/2014 @ 11:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 12:26
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2361835 Test Start : 12/09/2014 @ 09:54
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:49
Location : First Floor-C6C Received: 12/16/2014 @ 11:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 13:48
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361836 Test Start : 12/09/2014 @ 09:37
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:40
Location : First Floor-D1 Received: 12/16/2014 @ 11:00
Radon Level : 0.2 pCi/L Analyzed: 12/17/2014 @ 14:38
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2361849 Test Start : 12/09/2014 @ 09:53
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:49
Location : First Floor-C6G Received: 12/16/2014 @ 11:00
Radon Level : 0.4 pCi/L Analyzed: 12/16/2014 @ 12:26
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2361850 Test Start : 12/09/2014 @ 09:33
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:37
Location : First Floor-E2B Received: 12/16/2014 @ 09:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 16:15
Error for Measurement is: \pm 0.9 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Foreman Center Bldg 1
Test Location: 41 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2361851 Test Start : 12/09/2014 @ 09:25
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:36
Location : First Floor-F1 Received: 12/16/2014 @ 09:00
Radon Level : 0.2 pCi/L Analyzed: 12/17/2014 @ 16:32
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361852 Test Start : 12/09/2014 @ 09:52
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:47
Location : First Floor-C6F Received: 12/16/2014 @ 09:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 16:32
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2361853 Test Start : 12/09/2014 @ 10:04
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 13:55
Location : First Floor-B2/B3 Received: 12/16/2014 @ 12:00
Radon Level : 0.2 pCi/L Analyzed: 12/16/2014 @ 12:26
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2361854 Test Start : 12/09/2014 @ 10:55
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:26
Location : First Floor-D13A Received: 12/15/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 13:30
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361855 Test Start : 12/09/2014 @ 10:28
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:08
Location : First Floor-D15/C7 Received: 12/15/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/17/2014 @ 15:57
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/15/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-Client: Foreman Center Bldg 1
Test Location: 41 O'Connor Road
Fairport, NY 14450-
Individual Canister Results

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/citguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.

*Andreas C. George*Andreas C. George
Radon Measurement Specialist
NJ MES 11089*Dante Galan*Dante Galan
Laboratory DirectorNRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201