

Site Radon Inspection Report

Date : 12/10/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Building 4,5,6
Test Location: 38 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2346977 Test Start : 12/01/2014 @ 10:00
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:04
Location : First Floor-X-1 Received: 12/10/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/11/2014 @ 11:02
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2353089 Test Start : 12/01/2014 @ 11:23
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:43
Location : First Floor-BL Received: 12/10/2014 @ 14:00
Radon Level : 0.4 pCi/L Analyzed: 12/11/2014 @ 11:02
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2353142 Test Start : 12/01/2014 @ 11:13
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:35
Location : First Floor-W5 Received: 12/10/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/11/2014 @ 11:02
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2353147 Test Start : 12/01/2014 @ 11:05
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:29
Location : First Floor-X7 Hall Received: 12/10/2014 @ 14:00
Radon Level : 0.3 pCi/L Analyzed: 12/11/2014 @ 11:02
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2353148 Test Start : 12/01/2014 @ 10:42
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:24
Location : First Floor-X3 Received: 12/10/2014 @ 15:00
Radon Level : 0.4 pCi/L Analyzed: 12/10/2014 @ 15:51
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2353151 Test Start : 12/01/2014 @ 11:13
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:35
Location : First Floor-W Area Rear Received: 12/10/2014 @ 15:00
Radon Level : 0.3 pCi/L Analyzed: 12/11/2014 @ 10:39
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/10/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Building 4,5,6
Test Location: 38 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2353187 Test Start : 12/01/2014 @ 11:12
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:33
Location : First Floor-W8 Received: 12/10/2014 @ 15:00
Radon Level : 1.7 pCi/L Analyzed: 12/11/2014 @ 11:02
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2353194 Test Start : 12/01/2014 @ 11:23
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:43
Location : First Floor-BL Received: 12/10/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/11/2014 @ 10:39
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2353202 Test Start : 12/01/2014 @ 11:20
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:40
Location : First Floor-Cont Shop Received: 12/10/2014 @ 14:00
Radon Level : 0.5 pCi/L Analyzed: 12/10/2014 @ 16:55
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2353204 Test Start : 12/01/2014 @ 11:04
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:29
Location : First Floor-X7-Conf Received: 12/10/2014 @ 14:00
Radon Level : 0.6 pCi/L Analyzed: 12/10/2014 @ 16:11
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2353215 Test Start : 12/01/2014 @ 11:03
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:29
Location : First Floor-X7-Off Received: 12/10/2014 @ 14:00
Radon Level : 0.4 pCi/L Analyzed: 12/10/2014 @ 16:55
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2353216 Test Start : 12/01/2014 @ 11:08
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:31
Location : First Floor-W9 Received: 12/10/2014 @ 14:00
Radon Level : 1.2 pCi/L Analyzed: 12/11/2014 @ 11:02
Error for Measurement is: \pm 0.7 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/10/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Building 4,5,6
Test Location: 38 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2353217 Test Start : 12/01/2014 @ 11:21
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:41
Location : First Floor-W2 Tool Rm Received: 12/10/2014 @ 14:00
Radon Level : 0.2 pCi/L Analyzed: 12/11/2014 @ 11:02
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2353226 Test Start : 12/01/2014 @ 10:42
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:24
Location : First Floor-X3 Received: 12/10/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/11/2014 @ 10:39
Error for Measurement is: \pm 0.9 pCi/L

Canister ID# : 2353229 Test Start : 12/01/2014 @ 11:23
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:43
Location : First Floor-BL Received: 12/10/2014 @ 14:00
Radon Level : 0.3 pCi/L Analyzed: 12/11/2014 @ 10:39
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2357623 Test Start : 12/01/2014 @ 10:06
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:07
Location : First Floor-Y-4 Received: 12/10/2014 @ 14:00
Radon Level : 0.4 pCi/L Analyzed: 12/10/2014 @ 16:11
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2357715 Test Start : 12/01/2014 @ 10:00
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:04
Location : First Floor-X-1A Received: 12/10/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/10/2014 @ 16:11
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2357915 Test Start : 12/01/2014 @ 10:07
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:08
Location : First Floor-Y-5 Received: 12/10/2014 @ 14:00
Radon Level : 0.8 pCi/L Analyzed: 12/10/2014 @ 15:51
Error for Measurement is: \pm 0.7 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/10/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Building 4,5,6
Test Location: 38 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2357921 Test Start : 12/01/2014 @ 10:03
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:06
Location : First Floor-Y-2 Received: 12/10/2014 @ 14:00
Radon Level : 0.5 pCi/L Analyzed: 12/10/2014 @ 15:51
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2357925 Test Start : 12/01/2014 @ 10:08
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:08
Location : First Floor-Y-6 Received: 12/10/2014 @ 14:00
Radon Level : 0.2 pCi/L Analyzed: 12/10/2014 @ 15:51
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2357928 Test Start : 12/01/2014 @ 10:10
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:09
Location : First Floor-Y-7 Received: 12/10/2014 @ 15:00
Radon Level : 0.3 pCi/L Analyzed: 12/11/2014 @ 10:39
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2361086 Test Start : 12/01/2014 @ 10:09
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:09
Location : First Floor-Y-7 Received: 12/10/2014 @ 15:00
Radon Level : 0.6 pCi/L Analyzed: 12/10/2014 @ 15:51
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2361111 Test Start : 12/01/2014 @ 10:03
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:06
Location : First Floor-Y-2A Received: 12/10/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/10/2014 @ 16:11
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2361209 Test Start : 12/01/2014 @ 10:00
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:04
Location : First Floor-Y1C Received: 12/10/2014 @ 14:00
Radon Level : 0.6 pCi/L Analyzed: 12/10/2014 @ 16:11
Error for Measurement is: \pm 0.7 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/10/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Building 4,5,6
Test Location: 38 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2361211 Test Start : 12/01/2014 @ 10:10
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:09
Location : First Floor-Y-7 Received: 12/10/2014 @ 15:00
Radon Level : 0.6 pCi/L Analyzed: 12/10/2014 @ 16:55
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2361681 Test Start : 12/01/2014 @ 11:10
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:32
Location : First Floor-W10 Received: 12/10/2014 @ 15:00
Radon Level : 0.7 pCi/L Analyzed: 12/10/2014 @ 15:51
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361695 Test Start : 12/01/2014 @ 11:12
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:33
Location : First Floor-W8 Received: 12/10/2014 @ 15:00
Radon Level : 1.1 pCi/L Analyzed: 12/11/2014 @ 11:02
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2361701 Test Start : 12/01/2014 @ 10:30
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:18
Location : First Floor-X9C Received: 12/10/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/11/2014 @ 10:40
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2361740 Test Start : 12/01/2014 @ 11:17
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:38
Location : First Floor-W Area Mid Received: 12/10/2014 @ 14:00
Radon Level : 0.4 pCi/L Analyzed: 12/10/2014 @ 16:55
Tampered with. Opened.

Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361743 Test Start : 12/01/2014 @ 11:23
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:43
Location : First Floor-W1 Received: 12/10/2014 @ 14:00
Radon Level : 0.6 pCi/L Analyzed: 12/10/2014 @ 15:51
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/10/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Building 4,5,6
Test Location: 38 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2361752 Test Start : 12/01/2014 @ 10:29
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:18
Location : First Floor-X-9D Received: 12/10/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/11/2014 @ 10:39
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2361754 Test Start : 12/01/2014 @ 10:27
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:18
Location : First Floor-X10 Received: 12/10/2014 @ 14:00
Radon Level : 0.6 pCi/L Analyzed: 12/10/2014 @ 15:51
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2361757 Test Start : 12/01/2014 @ 11:17
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:38
Location : First Floor-W3 Received: 12/10/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/11/2014 @ 11:02
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2361760 Test Start : 12/01/2014 @ 10:32
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:20
Location : First Floor-X8 Received: 12/10/2014 @ 14:00
Radon Level : 0.5 pCi/L Analyzed: 12/11/2014 @ 11:02
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2361761 Test Start : 12/01/2014 @ 11:07
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:34
Location : First Floor-W7 Received: 12/10/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/10/2014 @ 16:55
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2361762 Test Start : 12/01/2014 @ 11:03
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:29
Location : First Floor-X7-Off Received: 12/10/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/11/2014 @ 11:02
Error for Measurement is: ± 0.8 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/10/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Building 4,5,6
Test Location: 38 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2361766 Test Start : 12/01/2014 @ 11:16
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:36
Location : First Floor-W4 Stor Received: 12/10/2014 @ 14:00
Radon Level : 0.4 pCi/L Analyzed: 12/10/2014 @ 16:55
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361769 Test Start : 12/01/2014 @ 10:23
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:15
Location : First Floor-X12 Received: 12/10/2014 @ 14:00
Radon Level : 0.4 pCi/L Analyzed: 12/10/2014 @ 15:51
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361771 Test Start : 12/01/2014 @ 10:28
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:18
Location : First Floor-X-10 Received: 12/10/2014 @ 15:00
Radon Level : 0.8 pCi/L Analyzed: 12/10/2014 @ 15:51
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361779 Test Start : 12/01/2014 @ 11:13
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:35
Location : First Floor-W5 Received: 12/10/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/11/2014 @ 10:39
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2361780 Test Start : 12/01/2014 @ 10:33
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:20
Location : First Floor-X8 Break Rm Received: 12/10/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/10/2014 @ 16:11
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361781 Test Start : 12/01/2014 @ 11:28
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:48
Location : First Floor-X16 Shop Received: 12/10/2014 @ 14:00
Radon Level : 0.6 pCi/L Analyzed: 12/11/2014 @ 10:39
Error for Measurement is: \pm 0.7 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/10/2014

Barbara Carlson
41 O'Connor Road
Rochesterser, NY 14450-

Client: Building 4,5,6
Test Location: 38 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2361783 Test Start : 12/01/2014 @ 10:20
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:13
Location : First Floor-Y11 Cage Received: 12/10/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/10/2014 @ 16:11
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2361790 Test Start : 12/01/2014 @ 10:16
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:10
Location : First Floor-Y-8 Received: 12/10/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/11/2014 @ 10:39
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2361800 Test Start : 12/01/2014 @ 10:31
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:19
Location : First Floor-X9 Received: 12/10/2014 @ 14:00
Radon Level : 1.4 pCi/L Analyzed: 12/10/2014 @ 16:55
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361801 Test Start : 12/01/2014 @ 10:19
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:13
Location : First Floor-Y11A Received: 12/10/2014 @ 14:00
Radon Level : 0.4 pCi/L Analyzed: 12/11/2014 @ 11:02
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361802 Test Start : 12/01/2014 @ 10:29
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:18
Location : First Floor-X9D Received: 12/10/2014 @ 15:00
Radon Level : 1.4 pCi/L Analyzed: 12/10/2014 @ 16:55
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361818 Test Start : 12/01/2014 @ 10:39
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:21
Location : First Floor-X2 Received: 12/10/2014 @ 14:00
Radon Level : 0.4 pCi/L Analyzed: 12/10/2014 @ 16:55
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/10/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Building 4,5,6
Test Location: 38 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2361822 Test Start : 12/01/2014 @ 10:56
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:25
Location : First Floor-X5-Sherry Received: 12/10/2014 @ 15:00
Radon Level : 0.4 pCi/L Analyzed: 12/11/2014 @ 10:40
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361824 Test Start : 12/01/2014 @ 11:23
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:43
Location : First Floor-W1 Received: 12/10/2014 @ 14:00
Radon Level : 0.4 pCi/L Analyzed: 12/10/2014 @ 15:51
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2361826 Test Start : 12/01/2014 @ 10:16
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:11
Location : First Floor-Y8 Received: 12/10/2014 @ 14:00
Radon Level : 1.0 pCi/L Analyzed: 12/10/2014 @ 16:55
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361829 Test Start : 12/01/2014 @ 10:55
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:25
Location : First Floor-X5-Anne Received: 12/10/2014 @ 15:00
Radon Level : 0.4 pCi/L Analyzed: 12/11/2014 @ 11:02
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2361830 Test Start : 12/01/2014 @ 10:40
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:24
Location : First Floor-X1 Received: 12/10/2014 @ 14:00
Radon Level : 0.8 pCi/L Analyzed: 12/10/2014 @ 15:51
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361839 Test Start : 12/01/2014 @ 10:31
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:19
Location : First Floor-X9 Received: 12/10/2014 @ 14:00
Radon Level : 0.6 pCi/L Analyzed: 12/10/2014 @ 16:55
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/10/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Building 4,5,6
Test Location: 38 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2361845 Test Start : 12/01/2014 @ 11:28
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:48
Location : First Floor-X16A Received: 12/10/2014 @ 16:49
Radon Level : 0.1 pCi/L Analyzed: 12/11/2014 @ 10:39
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361858 Test Start : 12/01/2014 @ 11:18
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:39
Location : First Floor-W Area Front Received: 12/10/2014 @ 14:00
Radon Level : 0.9 pCi/L Analyzed: 12/11/2014 @ 11:02
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2361871 Test Start : 12/01/2014 @ 11:24
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:43
Location : First Floor-Const Shop Received: 12/10/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/11/2014 @ 11:02
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361896 Test Start : 12/01/2014 @ 10:39
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:21
Location : First Floor-X2B Received: 12/10/2014 @ 14:00
Radon Level : 0.3 pCi/L Analyzed: 12/10/2014 @ 15:51
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2361897 Test Start : 12/01/2014 @ 10:19
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:13
Location : First Floor-Y11B Received: 12/10/2014 @ 14:00
Radon Level : 0.5 pCi/L Analyzed: 12/10/2014 @ 16:11
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361899 Test Start : 12/01/2014 @ 10:38
Canister Type : Charcoal Canister 3 inch Test Stop : 12/03/2014 @ 11:21
Location : First Floor-X2A Received: 12/10/2014 @ 15:00
Radon Level : 0.6 pCi/L Analyzed: 12/11/2014 @ 11:02
Error for Measurement is: \pm 0.7 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/10/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-Client: Building 4,5,6
Test Location: 38 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# :	2361906	Test Start :	12/01/2014 @ 10:18
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2014 @ 11:13
Location :	First Floor-Y11	Received:	12/10/2014 @ 14:00
Radon Level :	0.8 pCi/L	Analyzed:	12/10/2014 @ 16:55
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2361916	Test Start :	12/01/2014 @ 10:20
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/03/2014 @ 11:13
Location :	First Floor-Y11	Received:	12/10/2014 @ 14:00
Radon Level :	0.6 pCi/L	Analyzed:	12/10/2014 @ 15:51
Error for Measurement is: ±	0.5 pCi/L		

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/citguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.

Andreas C. George
Radon Measurement Specialist
NJ MES 11089Dante Galan
Laboratory DirectorNRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201