

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Building 9,10
Test Location: 25 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2353096 Test Start : 12/09/2014 @ 13:17
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:36
Location : First Floor-A7 Received: 12/16/2014 @ 12:00
Radon Level : 0.7 pCi/L Analyzed: 12/18/2014 @ 11:30
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2353097 Test Start : 12/09/2014 @ 13:20
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:36
Location : First Floor-A8 Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 13:01
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2353176 Test Start : 12/09/2014 @ 13:17
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:36
Location : First Floor-A9 Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/18/2014 @ 11:30
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2353213 Test Start : 12/09/2014 @ 13:13
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:36
Location : First Floor-A6 Received: 12/16/2014 @ 12:00
Radon Level : 1.1 pCi/L Analyzed: 12/18/2014 @ 11:13
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2353218 Test Start : 12/09/2014 @ 13:21
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:36
Location : First Floor-A5A Received: 12/16/2014 @ 12:00
Radon Level : 0.4 pCi/L Analyzed: 12/16/2014 @ 12:43
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2353239 Test Start : 12/09/2014 @ 13:17
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:36
Location : First Floor-A10 Received: 12/16/2014 @ 12:00
Radon Level : 1.3 pCi/L Analyzed: 12/18/2014 @ 11:30
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Building 9,10
Test Location: 25 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2357598 Test Start : 12/09/2014 @ 13:52
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:52
Location : First Floor-D3 Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/18/2014 @ 11:47
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2357611 Test Start : 12/09/2014 @ 13:32
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:41
Location : First Floor-C5D Received: 12/16/2014 @ 12:00
Radon Level : 0.2 pCi/L Analyzed: 12/18/2014 @ 13:16
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2357615 Test Start : 12/09/2014 @ 13:42
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:47
Location : First Floor-C2C Received: 12/16/2014 @ 12:00
Radon Level : 0.4 pCi/L Analyzed: 12/18/2014 @ 11:47
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2357619 Test Start : 12/09/2014 @ 13:37
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:44
Location : First Floor-C3B Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/18/2014 @ 11:30
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2357632 Test Start : 12/09/2014 @ 13:32
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:42
Location : First Floor-C5E Received: 12/16/2014 @ 12:00
Radon Level : 0.3 pCi/L Analyzed: 12/18/2014 @ 11:30
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2357636 Test Start : 12/09/2014 @ 14:01
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:56
Location : First Floor-Gym Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/18/2014 @ 11:47
Error for Measurement is: \pm 0.1 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Building 9,10
Test Location: 25 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2357648 Test Start : 12/09/2014 @ 13:31
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:42
Location : First Floor-C5A Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/18/2014 @ 13:16
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2357690 Test Start : 12/09/2014 @ 13:55
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:54
Location : First Floor-D8 Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 12:43
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2357696 Test Start : 12/09/2014 @ 13:28
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:40
Location : First Floor-A4 Received: 12/16/2014 @ 12:00
Radon Level : 0.6 pCi/L Analyzed: 12/18/2014 @ 11:30
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2357697 Test Start : 12/09/2014 @ 13:30
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:41
Location : First Floor-C5C Received: 12/16/2014 @ 12:00
Radon Level : 0.4 pCi/L Analyzed: 12/18/2014 @ 11:47
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2357704 Test Start : 12/09/2014 @ 13:55
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:54
Location : First Floor-D9 Received: 12/16/2014 @ 12:00
Radon Level : 0.4 pCi/L Analyzed: 12/18/2014 @ 11:13
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2357705 Test Start : 12/09/2014 @ 13:42
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:47
Location : First Floor-C2E Received: 12/16/2014 @ 12:00
Radon Level : 0.2 pCi/L Analyzed: 12/16/2014 @ 12:43
Error for Measurement is: \pm 0.3 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Building 9,10
Test Location: 25 O'Connor Road
Fairport, NY 14450-
Individual Canister Results

Canister ID# : 2357706 Test Start : 12/09/2014 @ 13:34
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:44
Location : First Floor-C30 Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/18/2014 @ 11:47
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2357708 Test Start : 12/09/2014 @ 13:31
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:41
Location : First Floor-C5B Received: 12/16/2014 @ 12:00
Radon Level : 0.4 pCi/L Analyzed: 12/18/2014 @ 11:13
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2357713 Test Start : 12/09/2014 @ 13:26
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:38
Location : First Floor-A2A Received: 12/16/2014 @ 12:00
Radon Level : 0.4 pCi/L Analyzed: 12/18/2014 @ 13:16
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2357714 Test Start : 12/09/2014 @ 13:40
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:46
Location : First Floor-C2A Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/18/2014 @ 11:30
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2357935 Test Start : 12/09/2014 @ 14:14
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 15:03
Location : First Floor-BL Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/18/2014 @ 11:47
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2358017 Test Start : 12/09/2014 @ 13:54
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:53
Location : First Floor-D6 Received: 12/16/2014 @ 12:00
Radon Level : 0.2 pCi/L Analyzed: 12/16/2014 @ 13:01
Error for Measurement is: ± 0.3 pCi/L



Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Building 9,10
Test Location: 25 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2358046 Test Start : 12/09/2014 @ 13:53
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:52
Location : First Floor-D4 Received: 12/16/2014 @ 12:00
Radon Level : 1.2 pCi/L Analyzed: 12/18/2014 @ 11:13
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361076 Test Start : 12/09/2014 @ 13:53
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:52
Location : First Floor-D5 Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 12:43
Error for Measurement is: \pm 0.9 pCi/L

Canister ID# : 2361087 Test Start : 12/09/2014 @ 14:05
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:58
Location : First Floor-F9 Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/18/2014 @ 11:47
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2361091 Test Start : 12/09/2014 @ 14:02
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:57
Location : First Floor-F4 Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/18/2014 @ 11:47
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2361102 Test Start : 12/09/2014 @ 13:27
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:39
Location : First Floor-A2F Received: 12/16/2014 @ 12:00
Radon Level : 0.2 pCi/L Analyzed: 12/18/2014 @ 11:13
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361107 Test Start : 12/09/2014 @ 13:43
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:47
Location : First Floor-C2D Received: 12/16/2014 @ 12:00
Radon Level : 0.8 pCi/L Analyzed: 12/18/2014 @ 11:30
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Building 9,10
Test Location: 25 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2361731 Test Start : 12/09/2014 @ 13:25
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:37
Location : First Floor-A2B Received: 12/16/2014 @ 12:00
Radon Level : 0.2 pCi/L Analyzed: 12/18/2014 @ 13:16
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361784 Test Start : 12/09/2014 @ 13:52
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:52
Location : First Floor-D2 Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 12:43
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361786 Test Start : 12/09/2014 @ 14:04
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:58
Location : First Floor-F5 Received: 12/16/2014 @ 12:00
Radon Level : 0.6 pCi/L Analyzed: 12/18/2014 @ 11:47
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361788 Test Start : 12/09/2014 @ 13:38
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:44
Location : First Floor-C3 Received: 12/16/2014 @ 12:00
Radon Level : 0.4 pCi/L Analyzed: 12/18/2014 @ 11:13
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361789 Test Start : 12/09/2014 @ 13:57
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:53
Location : First Floor-D10 Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 12:43
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361794 Test Start : 12/09/2014 @ 13:21
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:36
Location : First Floor-A5 Received: 12/16/2014 @ 12:00
Radon Level : 0.4 pCi/L Analyzed: 12/18/2014 @ 11:47
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Building 9,10
Test Location: 25 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2361799 Test Start : 12/09/2014 @ 14:01
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:56
Location : First Floor-Gym Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 12:43
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2361805 Test Start : 12/09/2014 @ 13:44
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:49
Location : First Floor-D1C Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/18/2014 @ 11:47
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2361806 Test Start : 12/09/2014 @ 14:06
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:59
Location : First Floor-F8 Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 12:43
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2361817 Test Start : 12/09/2014 @ 13:44
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:49
Location : First Floor-D1C Received: 12/16/2014 @ 12:00
Radon Level : 1.8 pCi/L Analyzed: 12/18/2014 @ 11:30
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361833 Test Start : 12/09/2014 @ 13:59
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:55
Location : First Floor-F1 Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/18/2014 @ 11:13
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2361838 Test Start : 12/09/2014 @ 13:42
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:48
Location : First Floor-C1 Received: 12/16/2014 @ 12:00
Radon Level : 0.5 pCi/L Analyzed: 12/16/2014 @ 13:01
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Building 9,10
Test Location: 25 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2361843 Test Start : 12/09/2014 @ 13:33
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:43
Location : First Floor-C4 Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 12:43
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2361870 Test Start : 12/09/2014 @ 14:05
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:58
Location : First Floor-F9 Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/18/2014 @ 11:30
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361873 Test Start : 12/09/2014 @ 14:09
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 15:02
Location : First Floor-E2 Received: 12/16/2014 @ 12:00
Radon Level : 0.3 pCi/L Analyzed: 12/18/2014 @ 11:47
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361876 Test Start : 12/09/2014 @ 14:14
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 15:03
Location : First Floor-BL Received: 12/16/2014 @ 12:00
Radon Level : 1.0 pCi/L Analyzed: 12/18/2014 @ 13:16
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361879 Test Start : 12/09/2014 @ 14:07
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 15:01
Location : First Floor-E2 Received: 12/16/2014 @ 12:00
Radon Level : 0.2 pCi/L Analyzed: 12/16/2014 @ 12:43
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361900 Test Start : 12/09/2014 @ 14:06
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:59
Location : First Floor-F7 Received: 12/16/2014 @ 12:00
Radon Level : 0.6 pCi/L Analyzed: 12/18/2014 @ 11:47
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Building 9,10
Test Location: 25 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2361903 Test Start : 12/09/2014 @ 14:12
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 15:03
Location : First Floor-C9 Received: 12/16/2014 @ 12:00
Radon Level : 0.2 pCi/L Analyzed: 12/16/2014 @ 12:43
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2361907 Test Start : 12/09/2014 @ 14:14
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 15:03
Location : First Floor-BL Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 12:43
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2361912 Test Start : 12/09/2014 @ 13:41
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:46
Location : First Floor-C2B Received: 12/16/2014 @ 12:00
Radon Level : 0.3 pCi/L Analyzed: 12/18/2014 @ 11:30
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2361918 Test Start : 12/09/2014 @ 14:06
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 15:00
Location : First Floor-E7 Received: 12/16/2014 @ 12:00
Radon Level : 0.4 pCi/L Analyzed: 12/16/2014 @ 12:43
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2361919 Test Start : 12/09/2014 @ 14:12
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 15:03
Location : First Floor-C6 Received: 12/16/2014 @ 12:00
Radon Level : 0.9 pCi/L Analyzed: 12/18/2014 @ 11:30
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2361922 Test Start : 12/09/2014 @ 14:03
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:57
Location : First Floor-F4A Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 12:43
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Building 9,10
Test Location: 25 O'Connor Road
Fairport, NY 14450-

Individual Canister Results

Canister ID# : 2361924 Test Start : 12/09/2014 @ 13:56
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:53
Location : First Floor-D10A Received: 12/16/2014 @ 12:00
Radon Level : 0.6 pCi/L Analyzed: 12/18/2014 @ 11:47
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2361925 Test Start : 12/09/2014 @ 13:54
Canister Type : Charcoal Canister 3 inch Test Stop : 12/11/2014 @ 14:57
Location : First Floor-D7 Received: 12/16/2014 @ 12:00
Radon Level : 0.1 pCi/L Analyzed: 12/18/2014 @ 11:47
Error for Measurement is: ± 0.8 pCi/L

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/citguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or it's consultants based on RTCA-provided results.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201