

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Morgan & Bird School
Test Location: 108-120 East Avenue
East Rochester, NY 14445-

Individual Canister Results

Canister ID# : 2357620 Test Start : 12/08/2014 @ 10:14
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:18
Location : Ground FI- BL Received: 12/16/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 14:48
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2357710 Test Start : 12/08/2014 @ 09:28
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:53
Location : Ground FI-B13A Received: 12/16/2014 @ 14:00
Radon Level : 0.6 pCi/L Analyzed: 12/16/2014 @ 14:28
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2357948 Test Start : 12/08/2014 @ 09:58
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:11
Location : Ground FI-M106B Received: 12/16/2014 @ 14:00
Radon Level : 0.6 pCi/L Analyzed: 12/16/2014 @ 15:18
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2357979 Test Start : 12/08/2014 @ 09:17
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:40
Location : Ground FI-B2 Received: 12/16/2014 @ 14:00
Radon Level : 0.9 pCi/L Analyzed: 12/16/2014 @ 15:18
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2357981 Test Start : 12/08/2014 @ 09:35
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:48
Location : Ground FI-B6 Received: 12/16/2014 @ 14:00
Radon Level : 0.3 pCi/L Analyzed: 12/16/2014 @ 14:48
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2358018 Test Start : 12/08/2014 @ 09:28
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:53
Location : Ground FI-B13B Received: 12/16/2014 @ 14:00
Radon Level : 0.8 pCi/L Analyzed: 12/16/2014 @ 14:48
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Morgan & Bird School
Test Location: 108-120 East Avenue
East Rochester, NY 14445-

Individual Canister Results

Canister ID# : 2358019 Test Start : 12/08/2014 @ 09:43
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:59
Location : Ground FI-B102-Off Received: 12/16/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 15:18
Error for Measurement is: \pm 0.9 pCi/L

Canister ID# : 2358021 Test Start : 12/08/2014 @ 09:45
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:01
Location : Ground FI-B115B Received: 12/16/2014 @ 14:00
Radon Level : 0.6 pCi/L Analyzed: 12/16/2014 @ 15:03
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2358024 Test Start : 12/08/2014 @ 10:07
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:14
Location : Ground FI-M108 R1A Received: 12/16/2014 @ 14:00
Radon Level : 0.4 pCi/L Analyzed: 12/16/2014 @ 15:03
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2358030 Test Start : 12/08/2014 @ 09:47
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:01
Location : Ground FI-B115Entry Received: 12/16/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 15:38
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2358038 Test Start : 12/08/2014 @ 09:53
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:08
Location : Ground FI-B104 Received: 12/16/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 14:47
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2358040 Test Start : 12/08/2014 @ 09:43
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:59
Location : Ground FI-B102-Off Received: 12/16/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 15:53
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Morgan & Bird School
Test Location: 108-120 East Avenue
East Rochester, NY 14445-

Individual Canister Results

Canister ID# : 2358042 Test Start : 12/08/2014 @ 09:24
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:46
Location : Ground FI-Gym Bird Received: 12/16/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 14:28
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2358047 Test Start : 12/08/2014 @ 08:50
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:26
Location : Ground FI-Time Out Rm Received: 12/16/2014 @ 14:00
Radon Level : 1.0 pCi/L Analyzed: 12/16/2014 @ 14:47
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2358062 Test Start : 12/08/2014 @ 09:51
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:06
Location : Ground FI-B113 Received: 12/16/2014 @ 14:00
Radon Level : 0.4 pCi/L Analyzed: 12/16/2014 @ 15:38
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2358064 Test Start : 12/08/2014 @ 09:46
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:01
Location : Ground FI-B115A Received: 12/16/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 14:47
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2358066 Test Start : 12/08/2014 @ 08:48
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:19
Location : Ground FI-Gym Received: 12/16/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 14:47
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361068 Test Start : 12/08/2014 @ 09:48
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:02
Location : Ground FI-B116 Received: 12/16/2014 @ 14:00
Radon Level : 0.3 pCi/L Analyzed: 12/16/2014 @ 15:18
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Morgan & Bird School
Test Location: 108-120 East Avenue
East Rochester, NY 14445-

Individual Canister Results

Canister ID# : 2361073 Test Start : 12/08/2014 @ 10:13
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:18
Location : Ground FI-Aud Received: 12/16/2014 @ 14:00
Radon Level : 0.5 pCi/L Analyzed: 12/16/2014 @ 15:18
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361082 Test Start : 12/08/2014 @ 09:23
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:45
Location : Ground FI-B12 Received: 12/16/2014 @ 14:00
Radon Level : 0.6 pCi/L Analyzed: 12/16/2014 @ 15:03
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361090 Test Start : 12/08/2014 @ 10:13
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:18
Location : Ground FI-Aud Received: 12/16/2014 @ 15:00
Radon Level : 0.6 pCi/L Analyzed: 12/16/2014 @ 15:53
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361095 Test Start : 12/08/2014 @ 08:47
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:19
Location : Ground FI-M11 Received: 12/16/2014 @ 14:00
Radon Level : 0.2 pCi/L Analyzed: 12/16/2014 @ 14:28
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2361103 Test Start : 12/08/2014 @ 08:47
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:19
Location : Ground FI-M14 Received: 12/16/2014 @ 14:00
Radon Level : 0.3 pCi/L Analyzed: 12/16/2014 @ 15:03
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361104 Test Start : 12/08/2014 @ 09:12
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:38
Location : Ground FI-A5 Received: 12/16/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 15:38
Error for Measurement is: \pm 0.3 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Morgan & Bird School
Test Location: 108-120 East Avenue
East Rochester, NY 14445-

Individual Canister Results

Canister ID# : 2361106 Test Start : 12/08/2014 @ 08:46
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:17
Location : Ground FI-M13 Received: 12/16/2014 @ 14:00
Radon Level : 0.2 pCi/L Analyzed: 12/16/2014 @ 14:48
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2361117 Test Start : 12/08/2014 @ 09:00
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:30
Location : Ground FI-M21 Received: 12/16/2014 @ 14:00
Radon Level : 0.4 pCi/L Analyzed: 12/16/2014 @ 14:48
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2361118 Test Start : 12/08/2014 @ 10:09
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:16
Location : Ground FI-M110 Received: 12/16/2014 @ 14:00
Radon Level : 0.4 pCi/L Analyzed: 12/16/2014 @ 15:03
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2361126 Test Start : 12/08/2014 @ 08:56
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:27
Location : Ground FI-M019 Received: 12/16/2014 @ 15:00
Radon Level : 0.6 pCi/L Analyzed: 12/16/2014 @ 15:53
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2361129 Test Start : 12/08/2014 @ 10:00
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:12
Location : Ground FI-M107 Received: 12/16/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 15:53
Error for Measurement is: ± 0.8 pCi/L

Canister ID# : 2361130 Test Start : 12/08/2014 @ 10:14
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:18
Location : Ground FI- BL Received: 12/16/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 14:48
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Morgan & Bird School
Test Location: 108-120 East Avenue
East Rochester, NY 14445-

Individual Canister Results

Canister ID# : 2361138 Test Start : 12/08/2014 @ 09:49
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:02
Location : Ground FI-B116 RstRm Received: 12/16/2014 @ 14:00
Radon Level : 0.3 pCi/L Analyzed: 12/16/2014 @ 15:18
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361189 Test Start : 12/08/2014 @ 09:10
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:37
Location : Ground FI-A1-Caf Received: 12/16/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 14:48
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361191 Test Start : 12/08/2014 @ 09:24
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:46
Location : Ground FI-Gym Bird Received: 12/16/2014 @ 15:00
Radon Level : 0.4 pCi/L Analyzed: 12/16/2014 @ 15:38
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361194 Test Start : 12/08/2014 @ 09:10
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:37
Location : Ground FI-AI Caf Received: 12/16/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 15:18
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2361201 Test Start : 12/08/2014 @ 09:18
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:41
Location : Ground FI-B2 Liv Rm Received: 12/16/2014 @ 15:00
Radon Level : 0.5 pCi/L Analyzed: 12/16/2014 @ 15:38
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2361203 Test Start : 12/08/2014 @ 08:57
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:27
Location : Ground FI-M019 Received: 12/16/2014 @ 15:00
Radon Level : 0.7 pCi/L Analyzed: 12/16/2014 @ 15:18
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Morgan & Bird School
Test Location: 108-120 East Avenue
East Rochester, NY 14445-

Individual Canister Results

Canister ID# : 2361212 Test Start : 12/08/2014 @ 10:13
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:18
Location : Ground FI- BL Received: 12/16/2014 @ 14:00
Radon Level : 0.9 pCi/L Analyzed: 12/16/2014 @ 15:03
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2361213 Test Start : 12/08/2014 @ 10:13
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:18
Location : Ground FI- BL Received: 12/31/-4714 @ 00:00
Radon Level : 0.8 pCi/L Analyzed: 12/16/2014 @ 15:38
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2361234 Test Start : 12/08/2014 @ 09:45
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:01
Location : Ground FI-B115C Received: 12/16/2014 @ 14:00
Radon Level : 0.5 pCi/L Analyzed: 12/16/2014 @ 15:03
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2361238 Test Start : 12/08/2014 @ 09:12
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:39
Location : Ground FI-A5 Received: 12/16/2014 @ 15:00
Radon Level : 0.6 pCi/L Analyzed: 12/16/2014 @ 15:53
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2361240 Test Start : 12/08/2014 @ 09:27
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:47
Location : Ground FI-B13C Received: 12/16/2014 @ 14:00
Radon Level : 0.7 pCi/L Analyzed: 12/16/2014 @ 15:18
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2361241 Test Start : 12/08/2014 @ 09:02
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:31
Location : Ground FI-Maint Off Storage Received: 12/16/2014 @ 14:00
Radon Level : 0.2 pCi/L Analyzed: 12/16/2014 @ 14:28
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Morgan & Bird School
Test Location: 108-120 East Avenue
East Rochester, NY 14445-

Individual Canister Results

Canister ID# : 2361244 Test Start : 12/08/2014 @ 09:32
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:52
Location : Ground FI-B8 Received: 12/16/2014 @ 14:00
Radon Level : 0.7 pCi/L Analyzed: 12/16/2014 @ 14:47
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361247 Test Start : 12/08/2014 @ 08:49
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:20
Location : Ground FI-M09 Received: 12/16/2014 @ 15:00
Radon Level : 0.2 pCi/L Analyzed: 12/16/2014 @ 15:38
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361248 Test Start : 12/08/2014 @ 09:17
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:40
Location : Ground FI-B2 Ldry Received: 12/16/2014 @ 14:00
Radon Level : 0.4 pCi/L Analyzed: 12/16/2014 @ 15:03
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361262 Test Start : 12/08/2014 @ 08:54
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:26
Location : Ground FI-M016A Received: 12/16/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 15:18
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2361635 Test Start : 12/08/2014 @ 10:06
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:14
Location : Ground FI-M108 Received: 12/16/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 14:47
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2361636 Test Start : 12/08/2014 @ 09:03
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:32
Location : Ground FI-M2 Received: 12/16/2014 @ 14:00
Radon Level : 1.3 pCi/L Analyzed: 12/16/2014 @ 15:03
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Morgan & Bird School
Test Location: 108-120 East Avenue
East Rochester, NY 14445-

Individual Canister Results

Canister ID# : 2361637 Test Start : 12/08/2014 @ 10:06
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:14
Location : Ground FI-M108 R1C Received: 12/16/2014 @ 14:00
Radon Level : 0.2 pCi/L Analyzed: 12/16/2014 @ 15:18
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361640 Test Start : 12/08/2014 @ 09:51
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:06
Location : Ground FI-B113 Rear Received: 12/16/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 14:28
Error for Measurement is: \pm 0.9 pCi/L

Canister ID# : 2361641 Test Start : 12/08/2014 @ 09:43
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:59
Location : Ground FI-B102 Received: 12/16/2014 @ 15:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 15:53
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2361667 Test Start : 12/08/2014 @ 10:14
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:18
Location : Ground FI-Stage Received: 12/16/2014 @ 15:00
Radon Level : 0.2 pCi/L Analyzed: 12/16/2014 @ 15:53
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2361668 Test Start : 12/08/2014 @ 08:48
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:19
Location : Ground FI-Gym Received: 12/16/2014 @ 15:00
Radon Level : 0.3 pCi/L Analyzed: 12/16/2014 @ 15:38
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361670 Test Start : 12/08/2014 @ 09:27
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:47
Location : Ground FI-B13C Received: 12/16/2014 @ 14:00
Radon Level : 0.6 pCi/L Analyzed: 12/16/2014 @ 14:28
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Morgan & Bird School
Test Location: 108-120 East Avenue
East Rochester, NY 14445-

Individual Canister Results

Canister ID# : 2361676 Test Start : 12/08/2014 @ 09:26
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:47
Location : Ground FI-B13 Received: 12/16/2014 @ 15:00
Radon Level : 0.4 pCi/L Analyzed: 12/16/2014 @ 15:18
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361680 Test Start : 12/08/2014 @ 08:55
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:26
Location : Ground FI-M016 Received: 12/16/2014 @ 15:00
Radon Level : 0.5 pCi/L Analyzed: 12/16/2014 @ 15:38
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361684 Test Start : 12/08/2014 @ 09:56
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:09
Location : Ground FI-M124 Received: 12/16/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 15:03
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361686 Test Start : 12/08/2014 @ 09:13
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:39
Location : Ground FI-A6 Received: 12/16/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 15:03
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361690 Test Start : 12/08/2014 @ 09:05
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:33
Location : Ground FI-M1 Received: 12/16/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 14:28
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2361693 Test Start : 12/08/2014 @ 09:01
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:30
Location : Ground FI-Maint Off Received: 12/16/2014 @ 14:00
Radon Level : 0.1 pCi/L Analyzed: 12/16/2014 @ 15:18
Error for Measurement is: \pm 0.3 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-

Client: Morgan & Bird School
Test Location: 108-120 East Avenue
East Rochester, NY 14445-

Individual Canister Results

Canister ID# : 2361866 Test Start : 12/08/2014 @ 10:09
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:16
Location : Ground FI-M110 Received: 12/16/2014 @ 14:00
Radon Level : 0.2 pCi/L Analyzed: 12/16/2014 @ 14:47
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361934 Test Start : 12/08/2014 @ 09:22
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:44
Location : Ground FI-B11 Received: 12/16/2014 @ 14:00
Radon Level : 0.5 pCi/L Analyzed: 12/16/2014 @ 15:03
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361937 Test Start : 12/08/2014 @ 09:44
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:01
Location : Ground FI-B115D Received: 12/16/2014 @ 14:00
Radon Level : 0.6 pCi/L Analyzed: 12/16/2014 @ 14:47
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361939 Test Start : 12/08/2014 @ 09:06
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:34
Location : Ground FI-M5 Received: 12/16/2014 @ 14:00
Radon Level : 0.8 pCi/L Analyzed: 12/16/2014 @ 15:03
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361940 Test Start : 12/08/2014 @ 09:57
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:10
Location : Ground FI-M106A Received: 12/16/2014 @ 14:00
Radon Level : 0.3 pCi/L Analyzed: 12/16/2014 @ 15:18
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361943 Test Start : 12/08/2014 @ 09:07
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:35
Location : Ground FI-M6 Received: 12/16/2014 @ 14:00
Radon Level : 0.9 pCi/L Analyzed: 12/16/2014 @ 15:03
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450

Client: Morgan & Bird School
Test Location: 108-120 East Avenue
East Rochester, NY 14445-

Individual Canister Results

Canister ID# : 2361952 Test Start : 12/08/2014 @ 09:18
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:42
Location : Ground FI-B10 Received: 12/16/2014 @ 15:00
Radon Level : 0.3 pCi/L Analyzed: 12/16/2014 @ 15:38
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361954 Test Start : 12/08/2014 @ 08:57
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:27
Location : Ground FI-M019 Received: 12/16/2014 @ 14:00
Radon Level : 0.6 pCi/L Analyzed: 12/16/2014 @ 14:28
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2361958 Test Start : 12/08/2014 @ 09:20
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:43
Location : Ground FI-B14 Received: 12/16/2014 @ 15:00
Radon Level : 0.6 pCi/L Analyzed: 12/16/2014 @ 15:38
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2361961 Test Start : 12/08/2014 @ 09:57
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:11
Location : Ground FI-M106 Received: 12/16/2014 @ 14:00
Radon Level : 0.3 pCi/L Analyzed: 12/16/2014 @ 15:18
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2361963 Test Start : 12/08/2014 @ 09:34
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 11:48
Location : Ground FI-B7 Received: 12/16/2014 @ 15:00
Radon Level : 0.3 pCi/L Analyzed: 12/16/2014 @ 15:38
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2361969 Test Start : 12/08/2014 @ 09:53
Canister Type : Charcoal Canister 3 inch Test Stop : 12/10/2014 @ 12:08
Location : Ground FI-B104 Received: 12/16/2014 @ 14:00
Radon Level : 0.3 pCi/L Analyzed: 12/16/2014 @ 14:47
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/16/2014

Barbara Carlson
41 O'Connor Road
Rochester, NY 14450-Client: Morgan & Bird School
Test Location: 108-120 East Avenue
East Rochester, NY 14445-
Individual Canister Results

Canister ID# :	2361971	Test Start :	12/08/2014 @ 10:07
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/10/2014 @ 12:14
Location :	Ground FI-M108 M108-R1B	Received:	12/16/2014 @ 14:00
Radon Level :	0.1 pCi/L	Analyzed:	12/16/2014 @ 15:03
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2361978	Test Start :	12/08/2014 @ 09:30
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/10/2014 @ 11:53
Location :	Ground FI-B9	Received:	12/16/2014 @ 14:00
Radon Level :	0.2 pCi/L	Analyzed:	12/16/2014 @ 15:03
Error for Measurement is: ±	0.8 pCi/L		

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/citguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.

Andreas C. George
Radon Measurement Specialist
NJ MES 11089Dante Galan
Laboratory DirectorNRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201