

Site Radon Inspection Report

Date : 12/08/2014

Barbara Carlson  
41 O'Connor Road  
Rochester, NY 14450-

Client: Staff Development  
Test Location: 15 Linden Park  
Rochester, NY 14625-

### Individual Canister Results

Canister ID# : 2346931                      Test Start : 12/01/2014 @ 13:40  
Canister Type : Charcoal Canister 3 inch          Test Stop : 12/03/2014 @ 14:19  
Location : First Floor-A9                      Received: 12/08/2014 @ 13:53  
Radon Level : 1.1 pCi/L                      Analyzed: 12/08/2014 @ 14:35  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2346936                      Test Start : 12/01/2014 @ 13:34  
Canister Type : Charcoal Canister 3 inch          Test Stop : 12/03/2014 @ 14:14  
Location : First Floor-B1                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.8 pCi/L                      Analyzed: 12/08/2014 @ 12:31  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2346975                      Test Start : 12/01/2014 @ 13:40  
Canister Type : Charcoal Canister 3 inch          Test Stop : 12/03/2014 @ 14:19  
Location : First Floor-A11                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.8 pCi/L                      Analyzed: 12/08/2014 @ 13:58  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2353088                      Test Start : 12/01/2014 @ 13:46  
Canister Type : Charcoal Canister 3 inch          Test Stop : 12/03/2014 @ 14:22  
Location : BL                                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.2 pCi/L                      Analyzed: 12/08/2014 @ 14:17  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2353152                      Test Start : 12/01/2014 @ 13:46  
Canister Type : Charcoal Canister 3 inch          Test Stop : 12/03/2014 @ 14:22  
Location : BL                                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.1 pCi/L                      Analyzed: 12/08/2014 @ 14:17  
Error for Measurement is:  $\pm$  0.3 pCi/L

Canister ID# : 2357593                      Test Start : 12/01/2014 @ 13:15  
Canister Type : Charcoal Canister 3 inch          Test Stop : 12/03/2014 @ 14:07  
Location : First Floor-D4                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.1 pCi/L                      Analyzed: 12/08/2014 @ 12:12  
Error for Measurement is:  $\pm$  0.3 pCi/L



*Andreas C. George*  
Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*  
Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/08/2014

Barbara Carlson  
41 O'Connor Road  
Rochester, NY 14450-

Client: Staff Development  
Test Location: 15 Linden Park  
Rochester, NY 14625-

### Individual Canister Results

Canister ID# : 2357595                      Test Start : 12/01/2014 @ 13:37  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:18  
Location : First Floor-A14                      Received: 12/08/2014 @ 13:53  
Radon Level : 1.0 pCi/L                      Analyzed: 12/08/2014 @ 14:17  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2357596                      Test Start : 12/01/2014 @ 13:41  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:21  
Location : First Floor-AHall                      Received: 12/08/2014 @ 13:53  
Radon Level : 1.3 pCi/L                      Analyzed: 12/08/2014 @ 14:17  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2357599                      Test Start : 12/01/2014 @ 13:09  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:01  
Location : First Floor-A1                      Received: 12/08/2014 @ 13:52  
Radon Level : 0.7 pCi/L                      Analyzed: 12/08/2014 @ 14:35  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2357600                      Test Start : 12/01/2014 @ 13:36  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:17  
Location : First Floor-CHall                      Received: 12/08/2014 @ 13:53  
Radon Level : 1.0 pCi/L                      Analyzed: 12/08/2014 @ 13:58  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2357604                      Test Start : 12/01/2014 @ 13:41  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:21  
Location : First Floor-AHall                      Received: 12/08/2014 @ 13:53  
Radon Level : 1.6 pCi/L                      Analyzed: 12/08/2014 @ 12:31  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2357617                      Test Start : 12/01/2014 @ 13:42  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:22  
Location : First Floor-A7                      Received: 12/08/2014 @ 13:53  
Radon Level : 1.5 pCi/L                      Analyzed: 12/08/2014 @ 14:17  
Error for Measurement is:  $\pm$  0.4 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/08/2014

Barbara Carlson  
41 O'Connor Road  
Rochester, NY 14450-

Client: Staff Development  
Test Location: 15 Linden Park  
Rochester, NY 14625-

Individual Canister Results

Canister ID# : 2357633                      Test Start : 12/01/2014 @ 13:11  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:03  
Location : First Floor-A2                      Received: 12/08/2014 @ 13:52  
Radon Level : 0.8 pCi/L                      Analyzed: 12/08/2014 @ 14:53  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2357646                      Test Start : 12/01/2014 @ 13:10  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 13:59  
Location : First Floor-Recpt                      Received: 12/08/2014 @ 13:52  
Radon Level : 0.8 pCi/L                      Analyzed: 12/08/2014 @ 14:35  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2357688                      Test Start : 12/01/2014 @ 13:12  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:05  
Location : First Floor-A3                      Received: 12/08/2014 @ 13:52  
Radon Level : 0.9 pCi/L                      Analyzed: 12/08/2014 @ 12:50  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2357691                      Test Start : 12/01/2014 @ 13:42  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:21  
Location : First Floor-A8                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.9 pCi/L                      Analyzed: 12/08/2014 @ 12:50  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2357694                      Test Start : 12/01/2014 @ 13:45  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:22  
Location : First Floor-A5                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.6 pCi/L                      Analyzed: 12/08/2014 @ 12:50  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2357700                      Test Start : 12/01/2014 @ 13:46  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:22  
Location : First Floor-A4                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.6 pCi/L                      Analyzed: 12/08/2014 @ 14:17  
Error for Measurement is:  $\pm$  0.4 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/08/2014

Barbara Carlson  
41 O'Connor Road  
Rochester, NY 14450-

Client: Staff Development  
Test Location: 15 Linden Park  
Rochester, NY 14625-

Individual Canister Results

Canister ID# : 2357711                      Test Start : 12/01/2014 @ 13:15  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:07  
Location : First Floor-C1                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.5 pCi/L                      Analyzed: 12/08/2014 @ 14:17  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2357907                      Test Start : 12/01/2014 @ 13:35  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:16  
Location : First Floor-D4                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.3 pCi/L                      Analyzed: 12/08/2014 @ 12:31  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2357918                      Test Start : 12/01/2014 @ 13:34  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:14  
Location : First Floor-B1                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.7 pCi/L                      Analyzed: 12/08/2014 @ 13:58  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2357930                      Test Start : 12/01/2014 @ 13:19  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:08  
Location : First Floor-D11                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.6 pCi/L                      Analyzed: 12/08/2014 @ 12:12  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2357938                      Test Start : 12/01/2014 @ 13:16  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:08  
Location : First Floor-D11                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.5 pCi/L                      Analyzed: 12/08/2014 @ 14:35  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2358037                      Test Start : 12/01/2014 @ 13:46  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:22  
Location : First Floor-A3 Copy                      Received: 12/08/2014 @ 13:53  
Radon Level : 1.2 pCi/L                      Analyzed: 12/08/2014 @ 14:35  
Error for Measurement is:  $\pm$  0.4 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/08/2014

Barbara Carlson  
41 O'Connor Road  
Rochester, NY 14450-

Client: Staff Development  
Test Location: 15 Linden Park  
Rochester, NY 14625-

Individual Canister Results

Canister ID# : 2358039                      Test Start : 12/01/2014 @ 13:33  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:14  
Location : First Floor-C2                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.8 pCi/L                      Analyzed: 12/08/2014 @ 12:31  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2358050                      Test Start : 12/01/2014 @ 13:22  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:10  
Location : First Floor-D8                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.7 pCi/L                      Analyzed: 12/08/2014 @ 14:35  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2358056                      Test Start : 12/01/2014 @ 13:32  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:13  
Location : First Floor-A10                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.8 pCi/L                      Analyzed: 12/08/2014 @ 14:35  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2358058                      Test Start : 12/01/2014 @ 13:13  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:05  
Location : First Floor-Cus Off                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.6 pCi/L                      Analyzed: 12/08/2014 @ 14:35  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2358060                      Test Start : 12/01/2014 @ 13:23  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:10  
Location : First Floor-D5                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.5 pCi/L                      Analyzed: 12/08/2014 @ 14:35  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2361070                      Test Start : 12/01/2014 @ 13:32  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:13  
Location : First Floor-A10                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.9 pCi/L                      Analyzed: 12/08/2014 @ 14:17  
Error for Measurement is:  $\pm$  0.4 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/08/2014

Barbara Carlson  
41 O'Connor Road  
Rochester, NY 14450-

Client: Staff Development  
Test Location: 15 Linden Park  
Rochester, NY 14625-

Individual Canister Results

Canister ID# : 2361078                      Test Start : 12/01/2014 @ 13:18  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:08  
Location : First Floor-D11                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.5 pCi/L                      Analyzed: 12/08/2014 @ 14:35  
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2361079                      Test Start : 12/01/2014 @ 13:38  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:18  
Location : First Floor-A12                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.7 pCi/L                      Analyzed: 12/08/2014 @ 12:12  
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2361084                      Test Start : 12/01/2014 @ 13:24  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:10  
Location : First Floor-D7                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.5 pCi/L                      Analyzed: 12/08/2014 @ 12:50  
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2361098                      Test Start : 12/01/2014 @ 13:35  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:16  
Location : First Floor-D4                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.7 pCi/L                      Analyzed: 12/08/2014 @ 14:17  
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2361132                      Test Start : 12/01/2014 @ 13:45  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:22  
Location : First Floor-A6                      Received: 12/08/2014 @ 13:53  
Radon Level : 1.2 pCi/L                      Analyzed: 12/08/2014 @ 12:50  
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2361142                      Test Start : 12/01/2014 @ 13:25  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:10  
Location : First Floor-D9                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.6 pCi/L                      Analyzed: 12/08/2014 @ 14:17  
Error for Measurement is: ± 0.4 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/08/2014

Barbara Carlson  
41 O'Connor Road  
Rochester, NY 14450-

Client: Staff Development  
Test Location: 15 Linden Park  
Rochester, NY 14625-

Individual Canister Results

Canister ID# : 2361147                      Test Start : 12/01/2014 @ 13:37  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:17  
Location : First Floor-B2                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.8 pCi/L                      Analyzed: 12/08/2014 @ 14:17  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2361148                      Test Start : 12/01/2014 @ 13:26  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:10  
Location : First Floor-DHall                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.6 pCi/L                      Analyzed: 12/08/2014 @ 14:35  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2361149                      Test Start : 12/01/2014 @ 13:19  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:08  
Location : First Floor-D11                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.4 pCi/L                      Analyzed: 12/08/2014 @ 14:35  
Error for Measurement is:  $\pm$  0.3 pCi/L

Canister ID# : 2361152                      Test Start : 12/01/2014 @ 13:11  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:04  
Location : First Floor-A3-Frink                      Received: 12/08/2014 @ 13:52  
Radon Level : 0.5 pCi/L                      Analyzed: 12/08/2014 @ 12:31  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2361264                      Test Start : 12/01/2014 @ 13:23  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:10  
Location : First Floor-D6                      Received: 12/08/2014 @ 13:53  
Radon Level : 0.9 pCi/L                      Analyzed: 12/08/2014 @ 12:12  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2361691                      Test Start : 12/01/2014 @ 13:38  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/03/2014 @ 14:18  
Location : First Floor-A13                      Received: 12/08/2014 @ 13:53  
Radon Level : 1.1 pCi/L                      Analyzed: 12/08/2014 @ 13:58  
Error for Measurement is:  $\pm$  0.4 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/08/2014

Barbara Carlson  
41 O'Connor Road  
Rochester, NY 14450-

Client: Staff Development  
Test Location: 15 Linden Park  
Rochester, NY 14625-  
Individual Canister Results

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon ([www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html)). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at [www.epa.gov/iaq/radon](http://www.epa.gov/iaq/radon).

**For New Jersey clients:** Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

**For New York clients:** If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

---

**PLEDGE OF ASSURED QUALITY**

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201